

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

December 27, 1983

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. James R. Miller, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 552A
NO/JHL:jab
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2
SUPPLEMENT TO PROPOSED TECHNICAL SPECIFICATIONS CHANGES

In our letter dated October 7, 1983 (Serial No. 552), Vepco requested an amendment in the form of changes to the Technical Specifications for North Anna Unit Nos. 1 and 2. These proposed changes would revise the Technical Specifications to reflect the addition of new fire protection systems.

This submittal will be a supplement to our above mentioned submittal, to add the statement that hose rack stations are located at the containment entrance. This statement should be added to the asterisk note on Table 3.7-7. The addition of this change will aid in completing the provisions of Appendix A to Branch Technical Position APCSB 9.5-1 and to clarify where the fire hose rack stations are located in relation to the containment. The proposed Technical Specification change for North Anna Unit No. 1 is provided in Attachment 1. The proposed Technical Specification change for North Anna Unit No. 2 is provided in Attachment 2. A discussion of the proposed Technical Specifications change is provided in Attachment 3.

This supplemented request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that this supplemental request does not involve an unreviewed safety question as defined in 10CFR50.59 and it does not pose a significant hazards consideration as defined in 10CFR50.92.

8401040424 831215
PDR ADOCK 05000338
P PDR


Adock
11/

VIRGINIA ELECTRIC AND POWER COMPANY TO

Mr. Harold R. Denton

We have reviewed this supplemental request in accordance with the criteria in 10CFR170.22. Since this request supplements a previous submittal, no additional license amendment fees are required.

Very truly yours,


W. L. Stewart

Attachments:

1. Proposed Technical Specification Change - Unit 1
2. Proposed Technical Specification Change - Unit 2
3. Discussion of Proposed Technical Specifications Change

cc: Mr. James P. O'Reilly
Regional Administrator
Region II

Mr. M. W. Branch
NRC Resident Inspector
North Anna Power Station

Mr. Charles Price
Department of Health
109 Governor Street
Richmond, Virginia 23219

Mr. L. D. Graber
LIS