

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

SCE

J. G. HAYNES
STATION MANAGER

TELEPHONE
(714) 492-7700

December 15, 1983

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
30-Day Report, Inoperable Fire Doors
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. B. Ray (SCE) to J. B. Martin (NRC),
dated November 15, 1983

In accordance with our referenced letter, this submittal provides the 30-day written report, pursuant to Technical Specification 6.9.1.13.b, for fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances.

Fire doors found inoperable during the November routine surveillances are identified in the Attachment and include: 11 latching mechanism failures; 22 closure mechanism failures; and 34 doors blocked open typically for construction, startup or maintenance activities. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established.

As reported previously, Design Change Packages (DCP's) are being developed to upgrade door latches and closures mechanisms into heavier duty hardware and to ensure a constant pressure differential across the access doors in the Radwaste and Control Buildings in order to reduce the door closure problems. The number of inoperable fire doors with these problems is decreasing, as these DCP's are implemented.

8401040474 831215
PDR ADDCK 05000361
S PDR

1/1 IP-22

December 15, 1983

Fire doors impaired for construction or maintenance activities were included in the Fire Barrier Removal and Reinstallation Request (FBRRR) Procedure effective December 8, 1983, to ensure proper compensatory measures are in place prior to any work performance. Results of the effectiveness of this revision will be reported in January. As long term corrective action, the installation of utility penetrations adjacent to the doors for the routing of temporary cables, conduits and/or hoses to avoid blocking open the fire doors is under consideration.

Results of surveillances conducted during December 1983 will be reported by January 18, 1983.

If you require any additional information, please so advise.

Sincerely,

JG Haynes

Attachment

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Division of Technical Information and Document Control

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF NOVEMBER 1983
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors failing - 11, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-105	11/01	11/09
	11/14	11/17
AC-106	11/01	Work Pending
AC-111	11/06	11/07
	11/08	11/11
	11/14	11/17
	11/18	11/21
AC-116	11/06	11/11
	11/14	11/21
AC-129	11/01	11/11
C2-201	11/21	11/30
AC-301	11/01	11/02
AC-349	11/18	11/29
FH2-403	11/15	11/17
AR-501	11/01	Work Pending
AR-504	11/01	Work Pending

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF NOVEMBER 1983
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Closure Mechanism Failures:

Number of doors failing - 22, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AR-101	11/30	Work Pending
FH2-101	11/01	11/14
	11/15	11/18
	11/21	Work Pending
	11/22	11/23
AR-104	11/30	Work Pending
	11/27	11/29
AC-115	11/07	11/11
AC-117	11/27	Work Pending
AC-128	11/27	11/28
DG2-204	11/26	11/27
AC-223	11/02	11/03
AC-301	11/12	11/14
FH2-302	11/01	11/18
	11/30	Work Pending
FH3-302	11/01	11/27
FH2-303	11/01	11/15
	11/16	11/18
AC-304	11/30	Work Pending
	11/01	11/07
FH2-304	11/23	11/24
AC-338	11/01	11/02
	11/11	11/13
AC-345	11/15	11/16
	11/01	11/02
	11/06	11/07
	11/09	11/10
	11/11	11/13
	11/15	11/16
AC-349	11/27	11/28
	11/01	11/10
AC-350	11/11	11/16
	11/06	11/07
	11/11	11/13
	11/15	11/17
C2-401	11/18	11/20
FH2-403	11/03	11/13
AR-404	11/24	11/27

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF NOVEMBER 1983
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS NO. 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

III. Doors Blocked Open:

Number of doors failing - 34, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AR-101	11/27	Work in Progress
DG2-101	11/24	11/25
PH2-103	11/26	11/29
AC-105	11/14	11/27
	11/29	Work in Progress
AC-111	11/01	11/02
AC-113	11/01	11-07
AC-115	11/17	11/18
	11/29	Work in Progress
AC-116	11/01	11/04
	11/10	Work in Progress
AC-125	11/01	Work in Progress
AR-203	11/27	Work in Progress
DG2-206	11/22	Work in Progress
AC-233	11/01	11/11
AC-239	11/18	11/21
AC-259	11/01	Work in Progress
AC-260	11/01	Work in Progress
AC-303	11/24	11/27
AC-306	11/26	11/27
AC-308	11/22	11/26
	11/29	Work in Progress
AC-312	11/05	11/11
AR-313	11/21	11/22
AR-315	11/21	11/28
AR-318	11/01	11/05
AC-319	11/22	11/26
AC-320	11/26	11/27
AC-331	11/16	11/17
	11/18	11/20
AC-338	11/05	11/11
C2-403	11/14	11/18
C2-404	11/03	11/05
	11/14	11/16
C3-404	11/28	11/29
AR-405	11/28	Work in Progress
AC-413	11/05	11/13
AC-442	11/01	11/07
	11/08	Work in Progress
AR-501	11/01	11/04
AR-509	11/23	11/24