

**LICENSEE EVENT REPORT**

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	I	L	D	R	S	2	2	0	0	-	0	0	0	0	0	0	3	4	1	1	1	1	4			5					
7	8	LICENSEE CODE						14		LICENSE NUMBER										25		LICENSE TYPE					30		57	CAT	58	

## REPORT

7 8 0 1 REPORT SOURCE L b 0 5 0 0 0 2 3 7 7 1 2 1 0 8 3 8 0 1 0 5 8 4 9  
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operations, while the operator was performing his once-per shift

0 3 | rounds, westside torus bulkhead door was found open. Contrary to Tech Spec 3.7.C.2,

0 4 | the radiation gate to this door was also found unlocked. There was no effect to

0 5 | public health and safety. The event is of minimal safety significance since the

0 6 | operability of the LPCI and core spray pumps were not affected. Last similar

0 7 | occurrence was reported by R.O. 82-39 on Docket #50-249.

[illegible]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The probable cause was a contractor who was in the area prior to that time. Oper-

1 1 | ator immediately closed and locked the door. Station department heads were reminded

1 2 | to inform their personnel of the requirement to have the bulkhead door closed at

1 3 | all times. In addition a memo was sent to the Station Construction Department

1 4 | which requested that contractors be reminded of these requirements.

8 9  
FACILITY STATUS      % POWER      OTHER STATUS (30)  
1 5 E (28) 0 9 9 (29) N/A  
7 8 9 10 11 12 13 44  
ACTIVITY CONTENT      METHOD OF DISCOVERY      DISCOVERY DESCRIPTION (32)  
1 6 Z (33) Z (34) N/A      B (31) Operator Inspections  
7 8 9 10 11 12 13 44 45 46 80  
RELEASED OF RELEASE      AMOUNT OF ACTIVITY (35)      LOCATION OF RELEASE (36)  
1 6 Z (33) Z (34) N/A      N/A  
7 8 9 10 11 12 13 44 45 46 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z (38) N/A				

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	3	0	0	0	(40) N/A

LOSS OF OR DAMAGE TO FACILITY		(43)
TYPE	DESCRIPTION	

1 9 7 8 9 10 N/A 8401130234 840105 PUBLICITY (45) NRC USE ONLY 80

ISSUED DESCRIPTION (45) PDR ADCK 05000237  
2 0 N (44) N/A S PDR

NAME OF PREPARER Anthony Anandappa

PHONE: (815) 942-2920 x548



**Commonwealth Edison**  
Dresden Nuclear Power Station  
R.R. #1  
Morris, Illinois 60450  
Telephone 815/942-2920

*D m B*

January 5, 1984

DJS ltr #84-21

James G. Keppler, Regional Administrator  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Reportable Occurrence Report #83-81/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(b), conditions leading to operation in a degraded mode permitted by a limiting condition for operation or plant shutdown required by a limiting condition for operation.

D.J. Scott  
Station Superintendent  
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: Director of Inspection & Enforcement  
Director of Management Information & Program Control  
U.S. NRC, Document Management Branch  
File/NRC

JAN 9 1984

IE221/1