


Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30308
Telephone 404 526-7726

Mailing Address:
Post Office Box 4545
Atlanta, Georgia 30302

D. O. Foster
Vice President and General Manager
Vogtle Project

USNRC MEMPHIS
ATLANTA, GEORGIA
03 DEC 6 A10: 37



November 28, 1983

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

File: X7BG10
Log: GN-288

Reference: 50-424/83-15, 50-425/83-15

Attention: Mr. R. C. Lewis

Gentlemen:

The Georgia Power Company wishes to submit the following information concerning the violation discussed in your inspection report 50-424/83-15 and 50-425/83-15:

Violation 50-424/83-15-01, "Failure to Provide for Code Required Penetrant Examination" - Severity Level IV.


- (1) Georgia Power Company acknowledges the discrepancy identified in this violation.
- (2) The reasons for the violation are as follows:
 - a. The piping contractor's (Pullman Power Products) engineer erroneously prepared the wrong process sheets for the welds on isometric drawing 1KA-1201-119-02, Rev. 10.
 - b. The piping contractor's QA document reviewer failed to detect the error in the process sheets.
- (3) The lack of penetrant examination requirements in process sheets associated with isometric drawing 1KA-1201-119-02, Rev. 10, is considered to be an isolated case. All other primary loop piping isometrics (twenty drawings in all) and all associated process sheets were examined and found to provide for penetrant examinations. Isometric drawing 1KA-1201-119-02, Rev. 10, and all associated process sheets, including the one for reactor coolant pressure boundary weld 119-W-05, have been revised to assure that required penetrant examinations are performed.
- (4) Pullman Power Products engineering and QA personnel have been admonished to review process sheets closely to assure compliance with all applicable requirements.

USNRC
November 28, 1983
Page 2

- (5) Full compliance with applicable regulatory and code requirements was achieved on November 16, 1983.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,


for D. O. Foster

REF/DOF/cc

xc: U. S. Nuclear Regulatory Commission
Attn: Victor J. Stello, Jr., Director
Office of Inspection and Enforcement
Washington, D. C. 20555

xc: R. J. Kelly	J. A. Bailey
R. E. Conway	O. Batum
G. F. Head	H. H. Gregory
J. T. Beckham	C. W. Hayes
D. N. MacLemore	E. D. Groover
D. E. Dutton	L. T. Gucwa
W. F. Sanders	M. Malcom
R. H. Pinson	G. Bockhold
B. M. Guthrie	P. D. Rice
R. A. Thomas	J. L. Vota