

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 2 200-000000-00 411111 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 L 05000316 1210983 010484 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 DURING NORMAL OPERATION, FIRE DOOR 472, IN THE 4KV ROOM WAS FOUND TO
03 OCCASIONALLY STICK IN THE FULL OPEN POSITION. THIS CONDITION CONSTITUTED
04 AN INOPERABLE PENETRATION FIRE BARRIER WHICH IS NONCONSERVATIVE WITH RESPECT
05 TO T.S.3.7.10. ACTION REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY
06 WERE NOT AFFECTED.
07
08

09 A B B C X X X X X X X Z Z
7 8 9 10 11 12 13 14 15 16
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

17 83 121 03 L 0
21 22 23 24 25 26 27 28 29 30 31
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

E Z Z Z 0000 N N A X999
33 34 35 36 37 38 39 40 41 42 43 44 45
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 THE BOTTOM OF THE DOOR WAS SCRAPING ON THE FLOOR WHEN IN THE FULL OPEN
11 POSITION, APPARENTLY DUE TO A PAINT BUILD-UP ON THE FLOOR. THE HIGH SPOT
12 IN THE FLOOR WAS GROUND DOWN AND THE MIDDLE AND LOWER DOOR HINGES WERE
13 SHIMMED TO PROVIDE ADEQUATE CLEARANCE. THE DOOR WAS TESTED AND RETURNED
14 TO SERVICE IN 22 HOURS AND 55 MINUTES.

15 E 100 NA B OPERATOR OBSERVATION
7 8 9 10 11 12 13 14 15 16 17 18 19 20
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 Z Z NA NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 000 Z NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 000 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
PERSONNEL INJURIES NUMBER DESCRIPTION

19 Z NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 N NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
PUBLICITY ISSUED DESCRIPTION

8401130345 840104
PDR ADOCK 05000316
S PDR

NAME OF PREPARER ROBERT H. PIEHL PHONE 616-465-5901

NRC USE ONLY
68 69 80 91-7-226