



**Wisconsin Electric** POWER COMPANY  
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

DMB

January 4, 1984

Mr. J. G. Keppler, Regional Administrator  
Office of Inspection and Enforcement,  
Region III  
U. S. NUCLEAR REGULATORY COMMISSION  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

DOCKET NOS. 50-266 AND 50-301  
FINAL RESPONSE TO IE BULLETIN 79-14  
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

IE Bulletin 79-14 required licensees to verify that the as-built safety-related piping systems conformed to the as-designed seismic analysis. This letter is our thirteenth submittal regarding IE Bulletin 79-14 and is intended to be our final response.

A total of 1,043 mechanical corrections were made to Point Beach Nuclear Plant, Units 1 and 2, to comply with the Bulletin. The last mechanical correction for each unit which required welding to the residual heat removal piping was installed during each unit's outage in 1983. As such, no additional analyses or hardware modifications are required.

All isometric drawings affected by the mechanical corrections have been revised and reissued showing the as-built configuration of the piping systems. Records of the calculations have been retained for use in any piping analyses required by future plant or system modifications.

Wisconsin Electric believes that all activities required by IE Bulletin 79-14 have been completed. If you have any questions or require additional information, please contact us.

Very truly yours,

Vice President-Nuclear Power

C. W. Fay

Copy to NRC Resident Inspector

8401130387 840104  
PDR ADOCK 05000266  
G PDR

JAN 9 1984

IEH 1/0