



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

MURRAY R. EDELMAN

VICE PRESIDENT  
NUCLEAR

December 22, 1983

Mr. James G. Keppler  
Regional Administrator, Region III  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
Extension Request Concerning the  
Governor Drive Coupling [RDC 59(82)]

Dear Mr. Keppler:

Our letter to you dated June 14, 1983, stated that the governors from the Standby Diesel Generators were being returned to the manufacturer for inspection, overhauling, and recalibration and that the rework necessary to correct the subject condition would be complete by October 31, 1983 (Unit 1), and December 31, 1983 (Unit 2).

The governors were returned from the manufacturer and the necessary rework for Unit 1 has been completed. However, rework for Unit 2 must be delayed to allow storage of the governors in the warehouse pending completion of other construction work in the immediate area. We now anticipate completion of Unit 2 work by May 1, 1984.

Please contact us if you have any questions.

Sincerely,

Murray R. Edelman  
Vice President  
Nuclear Group

8401050402 831222  
PDR ADOCK 05000440  
S PDR

MRE:pab

cc: Mr. M. L. Gildner  
NRC Site Office

Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
c/o Document Management Branch  
Washington, D.C. 20555

Records Center, SEE-IN  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339

IE271/0  
DEC 27 1983