



Carolina Power & Light Company

Brunswick Steam Electric Plant  
P. O. Box 10429  
Southport, NC 28461-0429

December 13, 1983

FILE: B09-13510A  
SERIAL: BSEP/83-3890

Mr. James P. O'Reilly, Administrator  
U. S. Nuclear Regulatory Commission  
Region II,  
Suite 3100, 101 Marietta Street N.W.  
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 & 2  
DOCKET NOS. 50-325 AND 50-324  
LICENSE NOS. DPR-71 AND DPR-62  
SUPPLEMENTAL RESPONSE TO IE BULLETIN 83-03

Dear Mr. O'Reilly:

In Carolina Power & Light Company's letter of June 8, 1983 (Serial No. BSEP/83-1627), CP&L committed to incorporate the eight diesel generator service water check valves (two per diesel generator) in a six-month periodic inspection program, perform an initial inspection of the valves during the fall outages, and submit a report of the initial inspection results. Periodic testing of the valves has been incorporated in plant procedure MI-10-521I and the initial inspections were completed on November 13, 1983. The valves were disassembled and all internal components appeared to be functioning properly with no evidence of deterioration. They were inspected in the presence of plant ISI personnel with cleanliness verified by QA prior to reassembly. CP&L hereby considers this IE Bulletin closed for the Brunswick station.

Very truly yours,

P. W. Howe, Vice President  
Brunswick Nuclear Project

RMP/jsa/LETJA

cc: NRC Document Control Desk

P. W. Howe, having been first duly sworn, did depose and say that the information contained herein is true and correct to his own personal knowledge or based upon information and belief.

8401050478 831213  
PDR ADOCK 05000324  
G PDR

Notary (Seal)

My commission expires: 3-22-87

JEH  
1/8