

DMB

Iowa Electric Light and Power Company
April 3, 1984
NG-84-1358

Mr. James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Duane Arnold Energy Center
Docket No: 50-331
Op. License No: DPR-49
NRC IE Bulletin No. 83-08, "Electrical Circuit
Breakers with an Undervoltage Trip Feature in
Safety-Related Applications Other than Reactor
Trip System."

Dear Mr. Keppler:

The subject bulletin requested that licensees identify applications of Westinghouse type DB and DS and GE type AK-2 circuit breakers which have undervoltage trip attachments in safety-related applications in their facilities, other than as Reactor Trip Breakers. Iowa Electric has reviewed in-plant documentation and has found no safety-related application of the above-mentioned circuit breakers in our facility.

Bulletin 83-08 also requested licensees identify safety-related applications of other types of breakers supplied by other manufacturers which have an undervoltage trip attachment. Iowa Electric has found no circuit breakers in a safety-related application which make use of a mechanical undervoltage trip attachment, as described in the subject bulletin, in our facility.

The above information is true and accurate to the best of my knowledge and belief. If you have further questions or comments, please contact this office.

As requested in the subject bulletin, the following information is provided to assist your cost evaluation of 83-08:

- Utility staff time to perform requested review	43 man-hours
- Utility staff time to prepare and review requested documentation	14 man-hours

8404160009 840403
PDR ADDCK 05000331
G PDR

APR 9 1984 IE 11
1/0

Mr. James Keppler
April 3, 1984
NG-84-1358
Page Two

IOWA ELECTRIC LIGHT AND POWER COMPANY

BY

Philip D. McGaughy for

Richard W. McGaughy
Manager, Nuclear Division

Subscribed and sworn to Before Me on
this 3rd day of April 1984.

Kathleen M. Surman
Notary Public in and for the State of Iowa

RWM/RAB/dmb*

cc: R. Browning
L. Liu
S. Tuthill
M. Thadani
NRC Resident Office
NRC Document Control Desk
Commitment Control No. 83-0345