

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A R A N 0 2 0 1 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 50

CON'T  
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 6 8 7 1 2 1 4 7 8 8 0 1 1 5 7 9 9  
7 8 9 DOCKET NUMBER 60 61 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During Low Power Physics Testing, Mode 3 operation, CEAC #1 was  
0 3 rendered inoperable. Leads were accidentally shorted to common while  
0 4 calibrating Digital-to-Analog converters in CPC Channel B. There have  
0 5 been no similar occurrences. Reported per T.S.6.9.1.9(b)  
0 6  
0 7  
0 8

0 9 SYSTEM CODE I C 11 CAUSE CODE A 12 CAUSE SUBCODE C 13 COMPONENT CODE I N S T R U 14 COM.P. SUBCODE Y 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 14 15 16  
17 LER/RO REPORT NUMBER 17 8 21 22 SEQUENTIAL REPORT NO. 0 2 5 24 25 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32  
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
ACTION TAKEN B 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER C 4 9 0 26  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Problem was corrected and CEAC #1 was returned to service within 2 hours  
1 1 meeting the requirements of Action Statement T.S. Table 3.3-1, Action Sa.  
1 2  
1 3  
1 4

1 5 FACILITY STATUS B 26 % POWER 0 0 0 29 OTHER STATUS 30 Low Power Phy. Test A 31 DISCOVERY DESCRIPTION 32  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
1 6 RELEASED OF RELEASE Z 33 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
2 0 PUBLICITY DESCRIPTION NA 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER Chris N. Shively

PHONE 501-968-2519

7901300068