

Detroit  
Edison

Douglas R. Gipson  
Senior Vice President  
Nuclear Generation

Fermi 2  
5400 North Dixie Highway  
Newport, Michigan 48166  
(313) 586-5249

10 CFR 50.73

May 9, 1995  
NRC-95-0049

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington D. C. 20555

Reference: Fermi 2  
NRC Docket No. 50-341  
NRC License No. NPF-43

Subject: Licensee Event Report (LER) No. 95-004

Please find enclosed LER 95-004, dated May 9, 1995, for a reportable event that occurred on April 9, 1995. The following commitments are made in this LER.

A review of the post scram feedwater logic modification will be conducted. Improvements to the system will be identified if possible to prevent reaching level 2 and will be evaluated for implementation.


Operator training for scram where Level 2 is reached will be reemphasized during Operator Requalification Training and will include recovery from recirculation pump trip/controlling heat uprate.

9505150198 950509  
PDR ADOCK 05000341  
S PDR

U. S. Nuclear Regulatory Commission  
May 9, 1995  
NRC-95-0049  
Page 2

A copy of this LER is also being sent to the Regional Administrator, USNRC Region III. If you have any questions, please contact Joseph M. Pendergast, Compliance Engineer at (313) 586-1682.

Sincerely,



Enclosure: NRC Forms 366, 366A

cc: T. G. Colburn  
J. B. Martin  
M. P. Phillips  
P. L. Torpey  
A. Vogel