

LICENSEE EVENT REPORT

CONTROL BLOCK: ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35

CONT

0	1	L	6	0	5	0	-	0	3	2	5	7	1	2	2	7	7	8	8	0	1	2	5	7	9	9	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

① Quarterly transmitter and recorder calibrations for drywell oxygen monitor CAC-AT-1259-2

② were not performed for Unit 1 in March 1978 and for Units 1 and 2 in September 1978.

③ However, CAC-AT-1259-2 analyzer calibrations were performed as required.

④ (Technical Specification 3.3.5.2)

⑤

⑥

⑦

⑧

0	9	S	E	11	D	12	Z	13	I	N	S	T	R	U	14	T	15	Z	16	7	8	—	0	8	5	—	0	3	L	—	0	17	7	8	—	0	8	5	—	0	3	L	—	0
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ⑳

① Analyzer, transmitter and recorder calibrations were completed in December 1978. The

② oxygen monitor analyzer is calibrated more frequently than the Technical Specifications

③ require. It was believed that the more frequent calibrations had also satisfied the

④ Technical Specification requirements for the transmitter and recorder. Upon evaluation

⑤ of the Technical Specifications requirements and the applicable (See Attached)

⑥

1	5	E	28	0	3	7	29	NA	30	B	31	Maintenance Review	32
7	8	9	10	11	12	13	14	15	16	17	18	19	20

1	6	Z	33	Z	34	NA	35	NA	36
7	8	9	10	11	12	13	14	15	16

1	7	0	0	0	37	Z	38	NA	39
7	8	9	10	11	12	13	14	15	16

1	8	0	0	0	40	NA	41
7	8	9	10	11	12	13	14

1	9	Z	42	NA	43
7	8	9	10	11	12

2	0	N	44	NA	45
7	8	9	10	11	12

NRC USE ONLY

7901300183

A. C. Tollison, Jr.

PHONE (919) 457-6701

LER CONTINUATION - RO# 1-78-085

Facility: BSEP Unit #1

Event Date: 12/27/78

Cause Description and Corrective Actions - Cont'd

calibration procedure, this was found not to be the case. A Periodic Test for the monitor will be written, approved, and entered into the Computer Periodic Test Schedule and performed on Units 1 and 2 by the end of March, 1979. These actions should prevent similar events from occurring.