



Carolina Power & Light Company

Brunswick Steam Electric Plant

P. O. Box 10429

Southport, NC 28461-0429

April 13, 1984

FILE: B09-13510C

SERIAL: BSEP/84-1035

NRC Document Control Desk

U. S. Nuclear Regulatory Commission

Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 2

DOCKET NO. 50-324

LICENSE NO. DPR-62

LICENSEE EVENT REPORT 2-84-1

Gentlemen:

On March 30, 1984, while performing Local Leak Rate Testing (LLRT) of Unit 2 Primary Containment Isolation Valves (PCIV) in accordance with PT-20.3, it was determined that type C leakage limits, as outlined in Technical Specification 3.6.1.2b, were exceeded for the Reactor feedwater line B inboard and outboard PCIVs. The required Licensee Event Report for this and any other LLRT reportable problems found during performance of the PT will be submitted within 30 days following completion of the PT.

Very truly yours,

C. R. Dietz, General Manager  
Brunswick Steam Electric Plant

MJP/shb/LETKB1

Enclosure

cc: Mr. J. P. O'Reilly

8404170094 840413  
PDR ADDCK 05000324  
S PDR

IE22  
1/0