

NRC Form 366  
(9-83)

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104

EXPIRES 8/31/85

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)

Grand Gulf Nuclear Station - Unit 1

DOCKET NUMBER (2)

0 5 0 0 0 4 1 6

PAGE (3)

1 OF 0 1

TITLE (4)

Elevator doors not verified shut

EVENT DATE (5)			LER NUMBER (6)		REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)			
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)	
0	3	1	4	8	4	0	1	2	0 0 0 4 1 0 8 4	NA	0 5 0 0 0 0
THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)											
OPERATING MODE (9)			20.402(b)		20.406(c)		50.73(a)(2)(iv)		73.71(b)		
POWER LEVEL (10)			20.406(a)(1)(i)		50.36(c)(1)		50.73(a)(2)(v)		73.71(c)		
0 0 0			20.406(a)(1)(ii)		50.36(c)(2)		50.73(a)(2)(vii)		OTHER (Specify in Abstract below and in Text, NRC Form 366A)		
			20.406(a)(1)(iii)		50.73(a)(2)(i)		50.73(a)(2)(viii)(A)				
			20.406(a)(1)(iv)		50.73(a)(2)(ii)		50.73(a)(2)(viii)(B)				
			20.406(a)(1)(v)		50.73(a)(2)(iii)		50.73(a)(2)(ix)				

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
Jerry Parker/Licensing Engineer	AREA CODE 6 0 1 4 3 7 - 2 1 4 9

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE)	NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR
<input type="checkbox"/>	<input checked="" type="checkbox"/>				

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

The elevator doors in the Control Building and Auxiliary Building are fire doors and are indicated as such in the FSAR. Technical Specification 4.7.7.2.d requires that unlocked fire doors without electrical supervision be verified closed at least once per 24 hours. On March 14, 1984, it was discovered that the surveillance which accomplishes this did not include the elevator doors. Although the doors were in fact operable and closed, this was not verified and documented each day. Therefore, this is reported as a violation of the Technical Specification. The surveillance has been revised to include the elevator doors. A check was made to ensure that all other fire doors were already included in the surveillances. This is a final report.

8404170128 840410  
PDR ADCK 05000416  
S PDR

IE 22 11



MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 10, 1984

NUCLEAR PRODUCTION DEPARTMENT

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Gentlemen:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File: 0260/L-835.0  
Elevator Doors Not Verified Shut  
LER 84-012-0  
AECM-84/0202

Attached is Licensee Event Report (LER) 84-012-0 which is a final report.

Yours truly,

L. F. Dale  
Manager of Nuclear Services

EBS/SHH:rg  
Attachment

cc: Mr. J. B. Richard (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. P. O'Reilly, Regional Administrator (w/a)  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303