



Nebraska Public Power District

COOPER NUCLEAR STATION
P.O. BOX 98, BROWNVILLE, NEBRASKA 68321
TELEPHONE (402)825-3811
FAX (402)825-5211

CENG958021

May 10, 1995

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555


Subject: Monthly Operating Status Report for April, Docket No. 50-298.

Gentlemen:

Enclosed for your information and use is the Cooper Nuclear Station Monthly Operating Status Report for April, 1995. The report includes Operating Status, Average Daily Unit Power Level, Unit Shutdown Data and a Narrative Summary of Operating Experience for the month of April.

Should you have any comments, or require additional information regarding this report, please contact me.

Sincerely,


J. T. Herron
Plant Manager

JTH:EAKK:djmc

Enclosures

cc: J. R. McPhail
R. L. Gangel
G. R. Horn
Div. Mgr. of Nuc. Eng. & Const.
A. L. Dostal
K. C. Walden
D. D. Rieger
E. A. Lanning
A. J. Hubl
R. L. Gumm
J. H. Mueller
NRC Senior Resident Inspector
T. H. Black
D. J. Morton-Chalé
R. J. Singer
T. L. Bundy
L. J. Callan
INPO Records Center
R. W. Beck and Associates
ANJ Library
E. J. Mroczka
H. J. Green
F. E. Yost

9505180240 950430
PDR ADDCK 05000298
R PDR

IFDA
11

OPERATING DATA REPORT

DOCKET NO. 050-0298
UNIT CNS
DATE May 10, 1995
TELEPHONE (402) 825-5829

OPERATING STATUS

1. Unit Name: Cooper Nuclear Station Notes
2. Reporting Period: April 1995
3. Licensed Thermal Power (MWt): 2381
4. Nameplate Rating (Gross MWe): 836
5. Design Electrical Rating (Net MWe): 778
6. Maximum Dependable Capacity (Gross MWe): 787
7. Maximum Dependable Capacity (Net MWe): 764
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
9. Power Level To Which Restricted, If Any (Net MWe):
10. Reasons For Restriction, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>719.0</u>	<u>2,879.0</u>	<u>182,616.0</u>
12. Number of Hours Reactor Was Critical	<u>719.0</u>	<u>1,763.0</u>	<u>134,953.2</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>719.0</u>	<u>1,640.5</u>	<u>132,919.8</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,705,392.0</u>	<u>3,800,264.0</u>	<u>275,111,508.0</u>
17. Gross Electric Energy Generated (MWH)	<u>565,233.0</u>	<u>1,249,350.0</u>	<u>89,367,695.0</u>
18. Net Electric Energy Generated (MWH)	<u>547,512.0</u>	<u>1,209,675.0</u>	<u>86,308,113.0</u>
19. Unit Service Factor	<u>100.0</u>	<u>57.0</u>	<u>72.8</u>
20. Unit Availability Factor	<u>100.0</u>	<u>57.0</u>	<u>72.8</u>
21. Unit Capacity Factor (Using MDC Net)	<u>99.7</u>	<u>55.0</u>	<u>61.9</u>
22. Unit Capacity Factor (Using DER Net)	<u>97.9</u>	<u>54.0</u>	<u>60.7</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>43.0</u>	<u>8.7</u>
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	<u>Refueling Outage, October 1995.</u>		

25. If Shut Down At End of Report Period, Estimated Date of Startup: N/A
26. Units In Test Status (Prior to Commercial Operation):
- | | |
|----------------------|----------|
| Forecast | Achieved |
| INITIAL CRITICALITY | |
| INITIAL ELECTRICITY | |
| COMMERCIAL OPERATION | |

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-0298
UNIT CNS
DATE May 10, 1995
TELEPHONE (402) 825-5829

MONTH April 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>764</u>	17	<u>764</u>
2	<u>731</u>	18	<u>762</u>
3	<u>765</u>	19	<u>763</u>
4	<u>764</u>	20	<u>763</u>
5	<u>764</u>	21	<u>762</u>
6	<u>764</u>	22	<u>757</u>
7	<u>765</u>	23	<u>709</u>
8	<u>764</u>	24	<u>765</u>
9	<u>763</u>	25	<u>764</u>
10	<u>764</u>	26	<u>764</u>
11	<u>764</u>	27	<u>763</u>
12	<u>765</u>	28	<u>760</u>
13	<u>764</u>	29	<u>758</u>
14	<u>766</u>	30	<u>764</u>
15	<u>765</u>		
16	<u>762</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	May 10, 1995
COMPLETED BY	E. A. Kernes Krause
TELEPHONE	(402) 825-5829

REPORT MONTH April 1995

[illegible]

1	2	3	4
F - Forced	Reason:	Method:	Exhibit G - Instructions for
S - Scheduled	A - Equipment Failure (Explain)	1 - Manual	Preparation of Data Entry
	B - Maintenance or Test	2 - Manual Scram	Sheets for Licensee Event
	C - Refueling	3 - Automatic Scram	Report (LER) File (NUREG-0161)
	D - Regulatory Restriction	4 - Continued	
	E - Operator Training & License Examination	5 - Reduced Load	5 Exhibit I - Same Source
	F - Administrative	6 - Other	
	G - Operational Error (Explain)		
	H - Other (Explain)		

**OPERATIONS NARRATIVE
COOPER NUCLEAR STATION**

April 1995

Cooper Nuclear Station operated at full power during the month of April, with turbine testing and control rod adjustments occurring on April 22 and 23.

Cooper attained a unit capacity factor of 99.7 percent (MDC Net) for the month of April.