

Thomas J. Martin  
Vice President  
Engineering and Construction

Public Service Electric and Gas Company 80 Park Plaza Newark, N.J. 07101 201/430-8316

March 28, 1984

Dr. Thomas E. Murley, Administrator  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Dear Mr. Murley:

NRC IE BULLETIN NO. 83-08 ELECTRICAL CIRCUIT BREAKERS  
WITH AN UNDERVOLTAGE TRIP FEATURE IN SAFETY RELATED  
APPLICATIONS OTHER THAN REACTOR TRIP SYSTEM  
HOPE CREEK GENERATING STATION

In a review of the Hope Creek design, it was found that no circuit breakers with an undervoltage trip attachment are used in safety related applications other than in the reactor trip system. The three types of circuit breakers specifically identified in Bulletin 83-08 are not utilized in the Hope Creek design.

This concludes our investigation for this Bulletin. Should additional information be desired, we will be pleased to discuss it with you.

Very truly yours,

*TJ Martin*

50-354  
355

8404170212 840328  
PDR ADOCK 05000354  
Q PDR

C Office of Inspection & Enforcement  
Division of Reactor Construction Inspection  
Washington, D.C. 20555

NRC Resident Inspector - Hope Creek  
P.O. Box 241  
Hancocks Bridge, New Jersey 08038

1/0 IE11