

6200 Oak Tree Boulevard
Independence OH
216-447-3153
Fax 216-447-3123

Mail Address:
P.O. Box 94661
Cleveland, OH 44101-4661

Donald C. Shelton
Senior Vice President
Nuclear

May 12, 1995
PY-CEI/OEPA-0222L

Ohio Environmental Protection Agency
P.O. Box 163669
Columbus, Ohio 43216-3669

Gentlemen:

Enclosed are the NPDES monthly report forms for the month of April, 1995.

If you have questions or require additional information, please contact
Donna T. Leno at (216) 280-5514.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'D. Shelton'.

Donald C. Shelton

DGT:sc

Enclosure

cc: NRC Project Manager
NRC Resident Inspector Office
NRC Document Control Desk (Docket No. 50-440)
NRC Region III

9505180520 950430
PDR ADOCK 05000440
R PDR

Operating Companies:
Cleveland Electric Illuminating
Toledo Edison

Handwritten: IER
IF25 '11

CLEVELAND ELECTRIC ILLUM CO 3IB00016001 APR 1995

1 1

OHIO

NUCLEAR GROUP

63461

C/O PERRY NUCLEAR POWER PLANT

10 CENTER ROAD ROOM E210

001 DISCHARGE FROM REGENERATE

NORTH PERRY 44081 LAKE

NEUTRALIZATION PITS

FORM

CEI, PERRY

J.J. GRIMM

	1 999	1 999	1 999	2 96	3 1
	CONDUI FLOW MGD	PH (MAX) S.U.	PH (MIN) S.U.	RESIDUE T NFLT MG/L	O&G TOTAL MG/L
	50050	00401	00402	00530	00550
01	AH	AH	AH		
02	AH	AH	AH		
03	AH	AH	AH		
04	AH	AH	AH		
05	AH	AH	AH		
06	AH	AH	AH		
07	0.0184	7.8	7.8	56	AA
08	AH	AH	AH		
09	AH	AH	AH		
10	0.0180	8.0	8.0	25	AA
11	0.0155	8.9	8.9		
12	AH	AH	AH		
13	AH	AH	AH		
14	AH	AH	AH		
15	0.0157	7.4	7.3		
16	AH	AH	AH		
17	AH	AH	AH		
18	AH	AH	AH		
19	AH	AH	AH		
20	0.0166	7.7	7.6	39	AA
21	AH	AH	AH		
22	AH	AH	AH		
23	AH	AH	AH		
24	0.0170	8.5	8.4	26	AA
25	AH	AH	AH		
26	AH	AH	AH		
27	AH	AH	AH		
28	AH	AH	AH		
29	AH	AH	AH		
30	AH	AH	AH		
31					
	0.1012	48.3	48.0	146	AA
	0.0169	8.1	8.0	37	AA
	0.0184	8.9	8.9	56	AA
	0.0155	7.4	7.3	25	AA

AA - BELOW DETECTABLE LIMIT (5 mg/l for O&G and 2.5 mg/l for RESIDUE)
 AH - SAMPLE NOT TAKEN, NO DISCHARGE PERFORMED THIS DATE



CLEVELAND ELECTRIC ILLUM CO 3IB00016800 APR 1995
NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E210
NORTH PERRY 44081 LAKE

1 1

OHIO
63461

800 INTAKE WATER AT INLET TO PLANT
FROM LAKE ERIE

FORM

CEI. PERRY

J.J. GRIMM

1
999

WATER
TEMP
F.

00011

01	39
02	40
03	40
04	40
05	39
06	39
07	39
08	39
09	40
10	39
11	38
12	37
13	40
14	41
15	42
16	42
17	43
18	43
19	43
20	44
21	44
22	45
23	45
24	45
25	45
26	45
27	46
28	47
29	48
30	47
31	


1264
42
48
37

NONE

REPORTER

T. H. Sommer for D. C. Skelton

3IB00016800



CLEVELAND ELECTRIC ILLUM CO 3IB00016004 APR 1995
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
63461

004 POINT REP OF DISCHARGE PRIOR TO
 ENTRY TO TUNNEL

FORM

CEI, PERRY

J.J. GRIMM

	1 999	1 999	3 1	3 1
	WATER TEMP F.	CONDUIT FLOW MGD	CHLOR FREE A MG/L	PH S.U.
	00011	50050	50064	00400
01	46	70.0	0.00	
02	44	72.4	0.00	
03	50	67.5	0.00	
04	48	74.9	0.00	8.3
05	45	73.7	0.00	
06	45	60.9	0.00	
07	48	72.1	0.00	8.3
08	48	72.7	0.00	
09	48	71.6	0.00	
10	45	66.9	0.00	
11	47	62.7	0.00	8.2
12	51	67.7	0.00	
13	54	68.8	0.00	
14	52	70.2	0.00	8.3
15	52	70.2	0.00	
16	53	74.9	0.00	
17	50	72.4	0.00	
18	50	94.4	0.00	8.2
19	50	84.4	0.00	
20	47	80.8	0.00	
21	49	76.9	0.00	8.2
22	53	74.8	0.00	
23	49	72.5	0.00	
24	47	62.3	0.00	
25	47	49.7	0.00	8.1
26	47	88.8	0.00	
27	48	85.5	0.00	
28	51	95.4	0.00	8.2
29	53	85.9	0.00	
30	53	80.2	0.00	
31				
	1470	2221.2	0.00	65.8
	49	74.0	0.00	8.2
	54	95.4	0.00	8.3
	44	49.7	0.00	8.1

NORMAL DISCHARGE FLOW REDUCED BECAUSE OF ONGOING SERVICE WATER SYSTEM
 OUTAGE AND PIPING INSPECTION.

REPORTER

T. Borman for DC Skotton

3IB00016004



CLEVELAND ELECTRIC ILLUM CO 3IB00016002 APR 1995
NUCLEAR GROUP
C/O PERRY NUCLEAR POWER PLANT
10 CENTER ROAD ROOM E210
NORTH PERRY 44081 LAKE

1 1

OHIO
63461

002 DISCHARGE FROM CHEMICAL CLEANING
LAGOON E PLANT

FORM

CEI, PERRY

J.J. GRIMM

1 999	1 999	2 96	3 1	2 96	2 96	2 96
CONDUI FLOW MGD	PH S.U.	RESIDUE T NFLT MG/L	O&G TOTAL MG/L	PHOS-T P-WET MG/L	COPPER CU.TOT MG/L	IRON FE.TOT MG/L
50050	00400	00530	00550	00665	01042	01045

01
02
03
04
05
06
07
08
09
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

NO DISCHARGE OCCURRED DURING THE MONTH

REPORTER

N.A. Bonner for D. Shetton

3IB00016002

