

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to L_a , 0.20% by weight of the containment air per 24 hours at a pressure not less than P_a , 37 psig, or
- b. A combined leakage rate of less than 0.60 L_a for all penetrations and valves subject to Type B and C tests, when pressurized to a pressure not less than P_a , 37 psig.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either the measured overall integrated containment leakage rate exceeding 0.75 L_a or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding 0.60 L_a , restore the overall integrated leakage rate to less than 0.75 L_a , and the combined leakage rate for all penetrations subject to Type B and C tests to less than 0.60 L_a prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

Except as modified by NRC approved exemptions

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR Part 50 using the methods and provisions of ANSI N45.4-1972:

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 ± 10 month intervals during shutdown at a pressure not less than P_a , 37 psig, during each 10-year service period. The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection;