

affected zone of weldments. Accordingly, although precise material data was not available, the ASME selected as conservative values for this criterion the yield strengths for A501 and A36 materials. See ASME interpretative letter, November 18, 1983, (Attachment).

John C. Finneran Jr.
John C. Finneran, Jr.

County of Somervell)
State of Texas)

Subscribed and sworn to before me
this 10th day of April, 1984

Cynthia Hammett
Notary Public