

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5					
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58			59

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Routine surveillance during plant operation revealed that primary containment

0 3 atmosphere oxygen analyzer, 2-CAC-AT-1263-2, was showing a slight step increase in

0 4 drywell oxygen concentration. On 12-23-82 and 12-26-82, 1263-2 was observed indicating

0 5 erratic indications of drywell oxygen concentration. At the time of each event

0 6 redundant instrument, 2-CAC-AT-1259-2, was showing expected drywell oxygen concentra-

0 7 tions. These events did not affect the health and safety of the public.

08 Technical Specifications 3.3.5.3, 3.6.6.4, 6.9.1.9b 80

SYSTEM CODE S E 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14			COMP. SUBCODE Y 15		VALVE SUBCODE Z 16						
EVENT YEAR 8 2 21 22		SEQUENTIAL REPORT NO. 1 4 0 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32									
ACTION TAKEN E 18		FUTURE ACTION C 19		EFFECT ON PLAN Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 40		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER B 1 3 5 26 44 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 1 The 12-21-82 and 12-26-82 events respectively occurred because 1263-2 was out of
1 1 calibration and had experienced an instrument zero shift. The 12-23-82 event resulted
1 2 from a small internal sample piping leak. After the 12-23-82 event, the sample piping
1 3 leak was repaired and following each event, 1263-2, Model No. F3M3, was recalibrated
1 4 and returned to service. These type CAC monitors are being replaced as per an approved
7 8 2 plant modification.

FACILITY STATUS (1) (5) (E) (28) % POWER (1) (0) (0) (29) OTHER STATUS (30) NA METHOD OF DISCOVERY (A) (31) DISCOVERY DESCRIPTION (32) Operator Surveillance

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 33 NA

7 8 9 10 11

AMOUNT OF ACTIVITY (35)

44

LOCATION OF RELEASE (36)

NA

45 80

PERSONNEL EXPOSURES										
NUMBER			TYPE		DESCRIPTION					
1	7		0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
1 8 0 0 0 (40) NA

LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION (43)

1 9 Z (42) NA S PDR ADOCK 05000324 PDR

PUBLICITY
ISSUED DESCRIPTION

(45)

N NA

NRC USE ONLY

PHONE: 919-457-9521