

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY

STATION MANAGER

January 12, 1983

RECEIVED
NRC

SCE

1983 JAN 14 AM 11:19

REGION V ARE

TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
14-Day Follow-Up Report
Licensee Event Report No. 82-150
San Onofre Nuclear Generating Station, Unit 2

Reference: Letter, H. B. Ray (SCE) to R. H. Engelken (NRC)
dated December 30, 1982, "24-Hour Confirmation
Letter, Licensee Event Report No. 82-150"

Pursuant to Section 6.9.1.12 of Appendix A, Technical Specifications to Facility Operating License NFP-10 for San Onofre Unit 2, this submittal provides the required 14-day written follow-up report and copy of the Licensee Event Report (LER) No. 82-150, regarding the improper installation of a valve in the Liquid Radwaste Monitor RT-7813.

On December 27, while performing maintenance on the Liquid Radwaste Monitor RT-7813 sample line, a Kerotest valve installed on the outlet side of the radiation detector was observed to have the flow indicator arrow pointing back toward the detector. On December 29, it was confirmed that the valve was incorrectly installed, and flow through the monitor was thereby restricted. Pursuant to Technical Specification 3.3.3.8, the monitor was declared inoperable and the required compensatory sampling program was initiated. On December 30, the valve was physically realigned, the monitor was flushed and cleaned, and was returned to operable status.

Subsequent investigation of maintenance and installation records indicates the valve was installed improperly. A physical inspection of all Kerotest valves associated with the Radiation Monitoring System is being conducted to verify correct installation position. This inspection program will be completed by February 1, 1983.

8302010138 830112
PDR ADOCK 05000361
S PDR

IE-22
83-18


January 12, 1983

A review of all liquid release records for Unit 2 was conducted. It has been confirmed that representative grab samples were taken and analyzed from all liquid process collection points prior to discharge. No effluent releases have exceeded Technical Specification limits.

There was no impact on the health and safety of the public or environment as a result of this event.

If you require any additional information regarding this item, please so advise.

Sincerely,



Enclosure: LER 82-150

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre, Unit 2)
R. J. Pate (USNRC Resident Inspector, San Onofre, Units 2 and 3)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information and Program Control

Institute of Nuclear Power Operations (INPO)