



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

January 17, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-078/03L-0
ER 100450 FILE 841-23
PLA- 1491

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-078/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.2.b, in that jet pumps 14 and 16 were not indicating during performance of surveillance testing.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8302010160 830117
PDR ADOCK 05000387
S PDR

terr