



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 25, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Hose Stations Rendered
Inoperable to Replace
Leaking Valve
LER 82-180/03 L-0
AECM-83/57

On December 27, 1982, a leaking isolation valve for a hose station in the control room area was replaced. To secure the station, the control building fire header was isolated and the action statements of Technical Specification 3.7.6.5 were followed. This event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 82-180/03 L-0.

Yours truly,

J.P. McGaughy, Jr.
FOR J.P. McGaughy, JR.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

IE 22

8302010171 830125
PDR ADOCK 05000416
S PDR