



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 24, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Barrier Found Open With
No Fire Watch Established
LER 83-004/01 T-0
AECM-83/53

On January 10, 1983, Field Engineering notified the Control Room that penetration AP-72B was open and had been so since December 13, 1982, with no fire watch established. At that time an hourly fire watch was established in accordance with Technical Specification 3.7.7.a. The penetration was opened to perform planned maintenance work. The event is reported pursuant to Technical Specification 6.9.1.12.b. Attached is LER 83-004/01 T-0.

Yours truly,

J. P. McGaughy
for J. P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302010172 830124
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY
IE 22