

LICENSEE EVENT REPORT

Attachment to AECEM-83/57

Page 1 of 1

CONTROL BLOCK:

						(1)
--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT	58

CON'T

REPORT SOURCE 0 1 7 8 L 6 0 5 0 0 0 4 1 6 7 1 2 2 7 8 2 8 10 1 2 5 8 3 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On December 27, 1982, the isolation valve for a hose station in the control room area
0 3 | was replaced. To secure the station, the control building fire header was isolated
0 4 | and the action statements of T.S.3.6.7.5 were followed. A fire door required by
0 5 | T.S.3.7.7 was blocked open to follow the required action statements. An hourly fire
0 6 | watch was established in accordance with T.S.3.7.7. This report is filed pursuant
0 7 | to T.S.6.9.1.13.b.
0 8 |

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
7 8		A B		E		B		V A L V E X				F		D					
		9 10		11 12		12 13		13 14 15 16 17 18				19 20		21 22					
17		EVENT YEAR				SEQUENTIAL REPORT NO.		OCCURRENCE CODE				REPORT TYPE		REVISION NO.					
LER/RO REPORT NUMBER		8 2		—		1 8 0		0 3				—		0					
		21 22		23		24 25 26		27 28 29				30 31		32					
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
C		Z		Z		Z		0 0 0 0				N		N		A		X 9 9 9	
33 34		35 36		37 38		39 40		41 42				43 44		45 46		47 48		49 50	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The Powhatatan isolation valve for the hose station was leaking and pressurized the
1 1 hose. Additional hose was run to supply backup fire protection in accordance with
1 2 T.S.3.7.6.5. The leaking valve was replaced and the system returned to service on
1 3 December 27, 1982. LCO duration was 3.7 hours. This is a final report.
1 4

FACILITY STATUS										% POWER				OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION									
1	5	G	28	0	0	0	29	NA				A	31	Planned Action															
ACTIVITY CONTENT										AMOUNT OF ACTIVITY				LOCATION OF RELEASE															
1	6	Z	33	Z	34	NA				NA																			
PERSONNEL EXPOSURES										DESCRIPTION																			
1	7	0	0	0	37	Z	38	NA																					
PERSONNEL INJURIES										DESCRIPTION																			
1	8	0	0	0	40	NA																							
LOSS OF OR DAMAGE TO FACILITY										DESCRIPTION				8302010181 830125 PDR ADOCK 05000416 S PDR															
1	9	Z	42	NA																									
PUBLICITY										DESCRIPTION				NRC USE ONLY															
2	0	N	44	NA																									

NAME OF PREPARED Original signed by M. Scott Freeman

PHONE: _____