

LICENSEE EVENT REPORT

Attachment to AECM-83/54
Page 1 of 1

CONTROL BLOCK:

--	--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

0 1 L 6 0 5 0 0 4 1 6 7 1 2 1 8 8 2 8 0 1 2 4 8 3 9

7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On December 18, 1982, several fire barriers in the Control Room floor were opened to reroute a cable through the floor. These barriers are required to be operable by T.S.3.7.7. This event had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a Special Report filed pursuant to T.S.3.7.7.a.

09		SYSTEM CODE A B		11	CAUSE CODE X		12	CAUSE SUBCODE Z		13	COMPONENT CODE Z Z Z Z Z Z Z						14	COMP. SUBCODE Z		15	VALVE SUBCODE Z		16			
7	8	9	10		11		12		13						18		19			20						
17		LER NO REPORT NUMBER		EVENT YEAR 8 2		21	22	SEQUENTIAL REPORT NO. 1 7 8		24	26	OCCURRENCE CODE 9 9		28	29	REPORT TYPE X		30	REVISION NO. 0		32					
ACTION TAKEN X		18	FUTURE ACTION Z		19	EFFECT ON PLANT Z		20	SHUTDOWN METHOD Z		21	HOURS 0 0 0 0		22	ATTACHMENT SUBMITTED N		23	NPRD-4 FORM SUB. N		24	PRIME COMP. SUPPLIER Z		25	COMPONENT MANUFACTURER Z 9 9 9		26
23	24		25		26		27		28		29		30		31		32		33		34		35		36	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The barriers were required to be open to reroute a cable through the floor. An LCO
1 1 | was initiated and an hourly fire watch was established in accordance with T.S.3.7.7.
1 2 | Work is currently in progress to restore the barriers. This should be completed
1 3 | within 60 days. This is an interim report. A final report will be submitted by
1 4 | March 25, 1983.

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	B	0	0	0	NA			A	Planned Action				
ACTIVITY CONTENT			RELEASED OF RELEASE			AMOUNT OF ACTIVITY			LOCATION OF RELEASE					
1	6	Z	Z	NA					NA					
PERSONNEL EXPOSURES			TYPE			DESCRIPTION								
1	7	0	0	Z	NA									
PERSONNEL INJURIES			TYPE			DESCRIPTION								
1	8	0	0	NA										
LOSS OF OR DAMAGE TO FACILITY			TYPE			DESCRIPTION								
1	9	Z	NA											
PUBLICITY			ISSUED			DESCRIPTION								
2	0	N	NA											

8302010200 830124
 PDR ADOCK 05000416
 S PDR

NRC USE ONLY

NAME OF PREPARER Original signed by M. Scott Freeman

PHONE: _____