

May 11, 1995

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

ULNRC-03211

Gentlemen:

**DOCUMENT NUMBER 50-483
CALLAWAY PLANT UNIT 1
FACILITY OPERATING LICENSE NPF-30
SPECIAL REPORT 95-01
NUMBER OF TUBES PLUGGED DURING THE EIGHTH
STEAM GENERATOR TUBE INSERVICE INSPECTION**

This special report is submitted in accordance with Technical Specification (T/S) 4.4.5.5.a, which states:

"Within 15 days following the completion of each inservice inspection of steam generator tubes, the number of tubes plugged in each steam generator shall be reported to the Commission in a Special Report pursuant to Specification 6.9.2."

The Steam Generator (S/G) Inservice Inspection was completed for S/G's 'B' and 'C' on 5/1/95 to meet the surveillance requirements of T/S 3/4.4.5, "Steam Generators". In addition, the discovery of stress corrosion cracking in S/G's 'B' and 'C' caused the scope of the inspection to be expanded to include using the motorized rotating pancake coil (MRPC) probe in all four S/G's. Forty (40) tubes were plugged as a result of the inspection and are identified on the following page. The plant was in Mode 6 - Refueling, with the core defueled for the planned Refuel VII outage.


160051

9505190314 950511
PDR ADOCK 05000483
Q PDR

A047
1/0

<u>S/G A</u>		<u>S/G B</u>		<u>S/G C</u>		<u>S/G D</u>	
<u>ROW</u>	<u>COLUMN</u>	<u>ROW</u>	<u>COLUMN</u>	<u>ROW</u>	<u>COLUMN</u>	<u>ROW</u>	<u>COLUMN</u>
X 21	47	49	33	1	1	1	1
11	50	47	65	37	18	33	56
12	51	50	91	14	41	X 16	61
X 18	54	1	120	36	43	17	108
X 13	55	1	121	12	55		
32	58			14	56		
12	61			46	56		
X 12	69			13	57		
X 14	69			14	57		
X 19	80			14	58		
34	100			X 15	58		
				13	59		
				X 15	60		
				13	61		
				X 14	61		
				54	63		
				43	80		
				24	88		
				14	100		
				45	101		

NOTE: X's indicate tubes with stabilizers installed.


 J. D. Blosser

JDB/HDB/MAH/lrj

Enclosure

cc: Distribution attached

SPECIAL REPORT 95-01

ULNRC-03211

cc distribution for ULNRC-03211

Mr. J. B. Martin
Regional Administrator
U. S. Nuclear Regulatory Commission
Region III
801 Warrenville Road
Lisle, IL 65032-4351

Mr. L. Raynard Wharton (2 copies)
U. S. Nuclear Regulatory Commission
OWFN - Mail Stop 13E21
Washington, D. C. 20555

Manager, Electric Department
Missouri Public Service Commission
P. O. Box 360
Jefferson City, MO 65102

Records Center Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, GA 30339

Mr. F. J. Farber
Chief, Reactor Projects Section III A
U. S. Nuclear Regulatory Commission
Region III
801 Warrenville Road
Lisle, IL 60532-4351

Mr. Thomas A. Baxter
Shaw, Pittman, Potts & Trowbridge
2300 N. Street N.W.
Washington, D.C. 20037

NRC Senior Resident Inspector