

LICENSEE EVENT REPORT

Attachment to AECM-83/59

Page 1 of 1

CONTROL BLOCK: 1 2 3 4 5 6 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	2	0	C	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5				
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57 CAT 58				

CON'T

0	1	L	6	0	5	0	0	0	4	1	6	7	1	2	2	8	8	2	8	0	1	2	7	8	3	9		
7	8	REPORT SOURCE					60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

On December 28, 1982, two fire rated doors in the Control Building (OC313 and OC503) were blocked open to perform a control room pressure test. These doors are required to be operable by T.S.3.7.7. This event had no effect on the health and safety of the public and did not constitute a threat to plant safety. The event is reported pursuant to T.S.6.9.1.13.b.

0	9	A	B	X	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z
7	8	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP SUBCODE		VALVE SUBCODE													
9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37

17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER		
82		181		03		L		0		X		Z		Z		0000		N		N		Z		Z999						

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ⑰

The doors were blocked open to perform a control room pressure test. An LCO was entered and a continuous fire watch was established in accordance with T.S.3.7.7. Once the control room pressure test was completed, the doors were closed. Total time in the LCO was 3.5 hours.

1	5	G	0	0	0	NA	A	Planned Action
7	8	9	10	11	12	13	14	15

1	6	Z	Z	NA	NA
7	8	9	10	11	12

1	7	0	0	0	Z	NA
7	8	9	10	11	12	13

1	8	0	0	0	NA
7	8	9	10	11	12

1	9	Z	NA
7	8	9	10

2	0	N	NA
7	8	9	10

NAME OF PREPARER Original signed by M. Scott Freeman

PHONE

NRC USE ONLY