

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

January 21, 1983

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET
NO. 50-396 - FACILITY OPERATING LICFNSR DPR-68 - REPORTABLE OCCURRENCE
REPORT BFRO-50-296/82067

The enclosed report provides details concerning the removal of 3C diesel-
generators from service to repair a coupling on the lube oil circulating
pump. This report is submitted in accordance with Browns Ferry unit 3
Technical Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY


H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

8302010270 830121
PDR ADOCK 05000296
S PDR

An Equal Opportunity Employer

OFFICIAL COPY

TE 22