



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 25, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Unit B Control Room Air
Conditioner Rendered
Inoperable Due to Failed
Trip Unit
LER 82-177/03 L-0
AECM-83/56

During shutdown operations, while attempting to start control room air conditioner Unit B, it was discovered that the common supply breaker for the fan and compressor was tripping as soon as it shut. This rendered Unit B inoperable and a Limiting Condition for Operation was entered under Technical Specification 3.7.2. Attached is LER 82-177/03 L-0.

Yours truly,

FOR J.P. McGaughy, Jr.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

TE 22

8302010425 830125
PDR ADCK 05000416
S PDR

Member Middle South Utilities System