

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L S L S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CONT
01 L 5 0 5 0 0 0 3 3 5 7 1 2 2 7 8 2 3 0 1 2 6 8 3 9

REPORT SOURCE 30 31 DOCKET NUMBER 38 39 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During normal full power operation, while performing a periodic CEA

03 exercise, CEA #43 slipped 45 inches, stopping at 87 inches. CEA #43 was

04 returned to group position and normal plant operation was resumed. This

05 was the second occurrence of a slipped CEA for which the cause is unknown.

06 (See LER 78-43). The health and safety of the public was not affected by

07 this event.

08

09

SYSTEM CODE R B 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE C R D R I V E 14 COMP TURCODE Z 15 VALVE SUBCODE Z 16

LER/RO REPORT NUMBER 17 8 2 21 22 SEQUENTIAL REPORT NO. 0 6 9 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 REVISION NO. 0 32

ACTION TAKEN Z 18 FUTURE ACTION Z 19 EFFECT ON PLANT B 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 4 22 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB N 24 PRIME COMP SUPPLIER N 25 COMPONENT MANUFACTURER C 4 9 0 25

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 No cause was found for CEA #43 slipping. CEA #43 was restored to its

11 normal position.

12

13

14

FACILITY STATUS E 28 % POWER 0 9 9 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE NA 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED DESCRIPTION N 44 NA 45

NAME OF PREPARER M. R. Hamby PHONE (305) 465-3550