



William J. Cahill, Jr.
Chief Nuclear Officer

May 12, 1995
JPN-95-025

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
**Proposed Changes to the Technical Specifications Regarding
Extension of Emergency Service Water System Surveillance Test
Intervals to Accommodate 24-Month Operating Cycles (JPTS-95-001F)**

Reference: 1. NRC Generic Letter 91-04, "Changes in Technical
Specification Surveillance Intervals to Accommodate
24-Month Fuel Cycle," dated April 2, 1991.

Dear Sir:

This application for an amendment to the James A. FitzPatrick Nuclear Power Plant Technical Specifications proposes to extend the surveillance test intervals for the emergency service water system to support 24 month operating cycles. The proposed changes follow the guidance of Generic Letter 91-04 (Reference 1). Approval of these changes will eliminate the need to schedule mid-cycle outages to conduct these surveillance tests.

Surveillance test interval extensions that are justified will be denoted as being performed "every 24 months" or "at least once per 24 months" consistent with the guidance provided in Reference 1. Other surveillances currently performed "once each operating cycle," "at least once during each operating cycle," "each refueling," or similar notation, that are not being extended at this time will be denoted as being performed "at least once per 18 months."

The signed original of the Application for Amendment to the Technical Specifications is enclosed for filing. Attachments I and III to this application contain the proposed changes to the Technical Specifications and a mark-up of the current Technical Specifications pages, respectively. Attachment II contains the associated Safety Evaluation for the emergency service water system.


9505230183 950512
PDR ADOCK 05000333
P PDR

ADD 1/1

In accordance with 10 CFR 50.91, a copy of this application and the associated attachments are being provided to the designated New York State official.

If you have any questions, please contact Ms. C. D. Faison.

Very truly yours,

A handwritten signature in dark ink, appearing to read "William J. Cahill, Jr.", with a stylized flourish at the end.

William J. Cahill, Jr.
Chief Nuclear Officer

cc: Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 136
Lycoming, NY 13093

Mr. C. E. Carpenter, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, NY 12223