



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 27, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303


Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Smoke Detectors Covered During
Planned Maintenance
Activities to Prevent False
Alarms
LER 82-179/03 L-0
AECM-83/61

From December 29, 1982, to January 17, 1983, smoke detectors were covered during planned maintenance activities to prevent false alarms and damage to the units. Hourly fire watches were established in accordance with Technical Specification 3.3.7.9. This is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 82-179/03 L-0.

Yours truly,


James P. McGaughy, Jr.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302030100 830127
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

ORIGINAL COPY

TE 22