



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

January 21, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-002/01P-0
ER 100450 FILE 841-23
PLA- 1498

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

This transmission confirms the telephone report of January 20, 1983, by D.G. Mitchell to E.C. McCabe of your staff, concerning a failure to perform the monthly channel functional test of the Main Steam Line Isolation Valve closure position switches as required by Technical Specification Table 4.3.1.1-1.

This event was found during a review of the plant matrix which contains Technical Specification surveillances, versus the implementing procedures. The testing requirements were immediately incorporated into the appropriate procedure and the functional testing of the position switches was successfully completed. A review is being conducted to determine if similar circumstances exist in other procedures.

This condition is considered reportable in accordance with Technical Specification 6.9.1.8.f.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

cc: Director, Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director, Office of Management & Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8302030223 830121
PDR ADOCK 05000387
S PDR

IE 29