



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

January 25, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-081/03L-0
ER 100450 FILE 841-23
PLA- 1503

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-081/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the Reactor Manual Control System panel indication failed. The RMCS could not be reset, therefore, control rod position could not be determined and they were declared inoperable.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

Attachment

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

IEU