



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 28, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 310  
Atlanta, Georgia 30303


Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Fire Rated Doors 1A202 and  
OC709 Blocked Open to  
Support Planned Maintenance  
Activities  
LER 82-182/03 L-0  
AECM-83/67

On December 29 and 31, 1982, two fire rated doors were blocked open to support planned maintenance activities. Limiting Conditions for Operations were initiated and fire watches were established in accordance with Technical Specification 3.7.7.a. This is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 82-182/03/L-0.

Yours truly,

  
FOR J. P. McGaughy, Jr.

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

6302030356 830128  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

ORIGINAL COPY  
1522