

LICENSEE EVENT REPORT

Attachment to AECM-83/67
Page 1 of 1

CONTROL BLOCK:

--	--	--	--	--	--

1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	2	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5
7	8	9					14	15									25	26					30			57	CAT 58
LICENSEE CODE		LICENSE NUMBER																LICENSE TYPE									

CONT

REPORT SOURCE 0 1 7 8 L 6 0 5 0 0 0 4 1 6 7 1 2 2 9 8 2 8 0 1 2 8 8 3 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Two Fire Rated Doors were blocked open to support planned maintenance activities (Door
0 3 1A202, on December 29 and OC709, on December 31). These doors were required to be
0 4 operable by T.S.3.7.7. This had no effect on the health and safety of the public and
0 5 did not constitute a threat to plant safety. This is reported pursuant to
0 6 T.S.6.9.1.13.b.
0 7
0 8

09		SYSTEM CODE		11	CAUSE CODE		12	COMPONENT CODE						14	COMP. SUBCODE		15	VALVE SUBCODE		16	
7	8	A	B		X			Z	Z	Z	Z	Z	Z	Z	Z	Z	Z				
17		EVENT YEAR		21	22	SEQUENTIAL REPORT NO.		24	25	26	OCCURRENCE CODE		28	29	REPORT TYPE		30	31	REVISION NO.		32
LER RO REPORT NUMBER		8	2			1	8	2				0	3						0		
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRC-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
X		Z		Z		Z		0	0	0	0	N		N		Z		Z	9	9	9
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The doors were opened in order to support planned maintenance. LCOs were initiated

1 1 | and fire watches were established in accordance with T.S.3.7.7 a. The maintenance

1 2 | work was completed and the doors were closed by January 3, 1983. This is submitted

1 3 | as a final report.

1 4 |

FACILITY STATUS
1 5 | G | 28 | 0 0 0 | 29 | NA | 44

% POWER
10 12 13

OTHER STATUS
30

METHOD OF DISCOVERY
A | 31 | Planned Action | 46

DISCOVERY DESCRIPTION
32

ACTIVITY CONTENT
RELEASED OF RELEASE
1 6 | 7 | 33 | Z | 34 | NA | 44

AMOUNT OF ACTIVITY
35

LOCATION OF RELEASE
NA | 45

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION
1 7 | 0 0 0 | 37 | Z | 38 | NA | 44

39

PERSONNEL INJURIES
NUMBER DESCRIPTION
1 8 | 0 0 0 | 40 | NA | 44

41

LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION
1 9 | Z | 42 | NA | 44

43

PUBLICITY
ISSUED DESCRIPTION
2 0 | N | 44 | NA | 44

45

8302030359 030128
PDR ADOCK 05000416
S PD

NRC USE ONLY

68 69

NAME OF PREPARER: Original signed by M. Scott Freeman

PHONE: _____