



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 28, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30302


Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Fire Doors OC409 and OC412  
Blocked Open to Perform  
Planned Maintenance  
Activities  
LER 82-186/99 X-0  
AECM-83/64

On December 23, 1982, two fire doors in the Control Building were blocked open in order to perform planned maintenance activities in the Control Room. Limiting Conditions for Operations were initiated and hourly fire watches were established in accordance with Technical Specification 3.7.7. Attached is Special Report LER 82-186/99 X-0.

Yours truly,

  
FOR: J. P. McGaughy, Jr.

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (v/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8302030363 83C128  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY  
16-22