

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT	58

CON'T

REPORT
SOURCE

0 1 7 8
REPORT SOURCE L 6 0 5 0 0 0 4 1 6 7 1 2 2 3 8 2 8 0 1 2 8 8 3 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On December 23, 1982, two fire doors in the Control Building (0C409 and 0C412) were

0 3 | blocked open to perform planned maintenance activities. These doors are required to

0 4 | be operable by T.S.3.7.7. This event had no effect on the health and safety of the

0 5 | public and did not constitute a threat to plant safety. This is a Special Report

0 6 | filed pursuant to T.S.3.7.7.a.

0	7	
0	8	

7 8 9

SYSTEM CODE A B (11)		CAUSE CODE X (12)		CAUSE SUBCODE Z (13)		COMPONENT CODE Z Z Z Z Z Z (14)						COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)			
EVENT YEAR 8 2 (21) (22)		SEQUENTIAL REPORT NO. 1 8 6 (24) (25) (26)		OCCURRENCE CODE 9 9 (28) (29)		REPORT TYPE X (30)		REVISION NO. 0 (32)									
ACTION TAKEN IV (33) (34)		FUTURE ACTION Z (35) (36)		EFFECT ON PLANT Z (37) (38)		SHUTDOWN METHOD Z (39) (40)		HOURS 0 0 0 0 (41) (42) (43) (44)		ATTACHMENT SUBMITTED N (45) (46)		NPRD-4 FORM SUB. N (47) (48)		PRIME COMP. SUPPLIER Z (49) (50)		COMPONENT MANUFACTURER Z 9 9 9 (51) (52) (53) (54)	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The doors were blocked open in order to perform planned maintenance activities in
1 1 the Control Room. LCO's were initiated and hourly fire watches were established in
1 2 accordance with T.S.3.7.7. The Control Room maintenance was completed and the fire
1 3 doors were closed on January 22, 1983. This is a final report.

1 4 7 8 9 80

7 8 9
FACILITY STATUS (1) 5 (G) (26)
% POWER (0) (0) (0) (29)
OTHER STATUS (30) A
METHOD OF DISCOVERY (A) (31) Planned Action
DISCOVERY DESCRIPTION (32)
44 45 46 80

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 Z (33) Z (34) NA
3 9 10 11 44

LOCATION OF RELEASE (36)
NA
45 80

PERSONNEL EXPOSURES		TYPE		DESCRIPTION
NUMBER				
1	7	0	0	0
		37	Z	38
				NA

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
NA			

7		8		9		10		11		12		
LOSS OF OR DAMAGE TO FACILITY						(43)						
TYPE						DESCRIPTION						
1	9	2	(42)	NA								80

8 9 10
PUBLCITY
ISSUED DESCRIPTION (45)
2 0 [N] (44)
2 9 0 10
B302030367 830128
PDR ADOCK 05000416
S PDR
NRC USE ONLY
68 69 70 71 72 73 74 75 76 77 78 79 80

NAME OF PREPARER Original signed by M. Scott Freeman

PHONE: _____