



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 28, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303


Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Smoke Detection Zone 2-14  
Alarmed and Would Not Reset  
LER 82-184/03 L-0  
AECM-83/65

On December 29, 1982, smoke detection Zone 2-14 alarmed with no smoke or fumes present and would not reset. The alarm was deactivated and an hourly fire watch was established in accordance with Technical Specification 3.3.7.9.a. This event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 82-184/03 L-0.

Yours truly,

  
FOR J.P. McLaughy Jr.

JPM:sap  
Attachment

c Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8302030387 830128  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY  
FE 22