

LICENSEE EVENT REPORT

Attachment to AECM-83/65

Page 1 of 1

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M S G G S 1 2 0 0 - 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

01 L 6 0 5 0 0 0 4 1 6 7 1 2 2 9 8 2 8 0 1 2 8 8 3 9

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On December 29, 1982, smoke detection Zone 2-14 (RHR C and LPC Pump Rooms) alarmed

03 with no smoke or fumes present and would not reset. The alarm was deactivated and

04 an hourly fire watch was established in accordance with T.S.3.3.7.9.a. The event had

05 no effect on the health and safety of the public and did not constitute a threat to

06 plant safety. This is reported pursuant to T.S.6.9.1.13.b.

07 _____

08 _____

09 A B 11 X 12 Z 13 I N S T R U 14 E 15 Z 16

SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 18 COMP SUBCODE 19 VALVE SUBCODE 20

17 8 2 1 8 4 0 3 L 0

LER/RO REPORT NUMBER 21 22 SEQUENTIAL REPORT NO. 23 24 26 OCCURRENCE CODE 28 29 REPORT TYPE 30 31 REVISION NO. 32

X 18 Z 19 7 20 Z 21 0 0 0 0 N 23 N 24 A 25 H 2 6 0 26

ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 40 ATTACHMENT SUBMITTED 41 NPRD-4 FORM SUB. 42 PRIME COMP. SUPPLIER 43 COMPONENT MANUFACTURER 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Upon investigation by maintenance, the smoke detection zone was found functionally

11 operable and was reset. The cause of the alarm is attributed to spurious actuation.

12 The zone was restored to operability on January 12, 1983. The total time of the LCO

13 was 13 days, 5 hours. This is submitted as a final report.

14 _____

15 G 28 0 0 0 29 NA A 31 Alarmed C dition 32

FACILITY STATUS 7 8 9 % POWER 10 12 OTHER STATUS 13 30 METHOD OF DISCOVERY 45 46 DISCOVERY DESCRIPTION 47 80

16 Z 33 7 34 NA NA 36

ACTIVITY CONTENT 7 8 9 RELEASED OF RELEASE 10 11 AMOUNT OF ACTIVITY 12 35 LOCATION OF RELEASE 13 36

17 0 0 0 37 Z 38 N 39

PERSONNEL EXPOSURES 7 8 9 NUMBER 10 11 TYPE 12 13 DESCRIPTION 14 39

18 0 0 0 40 NA 41

PERSONNEL INJURIES 7 8 9 NUMBER 10 11 DESCRIPTION 12 41

19 Z 42 NA 43

LOSS OF OR DAMAGE TO FACILITY 7 8 9 TYPE 10 11 DESCRIPTION 12 43

20 N 44 8302030393 830128 PDR ADOCK 05000416 S PDR

PUBLICITY 7 8 9 ISSUED 10 11 DESCRIPTION 12 45

NRC USE ONLY 68 69 80

NAME OF PREPARER Original signed by Ron Byrd

PHONE _____