



PECO ENERGY

PECO Energy Company
Nuclear Group Headquarters
965 Chesterbrook Boulevard
Wayne, PA 19087-5691

May 15, 1995

Docket Nos. 50-352
50-353

License Nos. NPF-39
NPF-85

NPDES Permit No. PA0051926

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Limerick Generating Station, Units 1 and 2
Changes to National Pollutant Discharge
Elimination System Permit

Gentlemen:

This letter is being submitted in accordance with the Limerick Generating Station (LGS), Units 1 and 2, Environmental Protection Plan (EPP) Section 3.2, which stipulates that the NRC shall be notified within 30 days following the date of approval of a change to the National Pollutant Discharge Elimination System (NPDES) permit.

By letter dated May 5, 1995, the Pennsylvania Department of Environmental Resources (PA DER) approved our request to establish two (2) internal monitoring points (i.e., 103 and 105) for monitoring condenser waterbox drain down discharges to the Possom Hollow Run through Outfalls 003 and 005. A copy of the PA DER letter approving this NPDES permit revision is attached. The NRC was previously notified of our request to establish these two (2) internal monitoring points by letter dated February 2, 1995.

If you have any questions or require additional information, please do not hesitate to contact us.

Very truly yours,

G. A. Hunger, Jr.
Director - Licensing

Attachment

9505240176 950515
PDR ADOCK 05000352
P PDR

cc: T. T. Martin, Administrator, Region I, USNRC (w/ attachment)
N. S. Perry, USNRC Senior Resident Inspector, LGS (w/ attachment)

JE23/1

ATTACHMENT



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES

Lee Park, Suite 6010
555 North Lane
Conshohocken, PA 19428

RECEIVED

MAY 05 1995

MAY 09 1995

(610) 832-6130

W.F. McELROY (610) 832-6259

Southeast Regional Office

Robert M. Matty, Jr., Engineer
PECO Energy Company
2301 Market Street
P.O. Box 8699
Philadelphia, PA 19101-8699

Re: Industrial Waste NPDES Permit
PA 0051926 Amendment No. 1
PECO Energy Company
Limerick Township
Montgomery County

Dear Mr. Matty:

Referenced amended permit pages 1 and 2e are enclosed.

It will be necessary for you to submit a completed Discharge Monitoring Report (DMR) on a monthly basis to the appropriate agencies (see p. 5 of the NPDES permit).

A master copy of an amended DMR form is enclosed which should be reproduced for your use in this regard.

Please study the amended permit pages carefully and substitute these pages for those similarly numbered pages in your permit issued December 12, 1994. Please direct any questions to the Permits Section of this office.

Sincerely,

Charles Rehm
Acting Regional Manager
Water Management Program

Enclosures: Permit Pages 1 and 2e
Master Discharge Monitoring Report (Amendment No. 1 for MP 103 and MP 105)

cc: Operations
EPA
DRBC
Limerick Township (Transmittal letter only)
Permits & Compliance
Operations Section
Re 30 (RN)3



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES
WATER MANAGEMENT PROGRAMAUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEMINDUSTRIAL NPDES PERMIT NO. PA 0051926 Amendment No. 1

In compliance with the provisions of the Clean Water Act, 33 U.S.C. Section 1251 et seq. (the "Act") and Pennsylvania's Clean Streams Law, as amended, 35 P.S. Section 691.1 et seq.,

PECO Energy Company

is authorized to discharge from a facility located at

Evergreen and Sanatoga RoadLimerick, PAMunicipality Limerick TownshipCounty Montgomery County

to receiving waters named

Schuylkill River and Possum Hollow Run

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts A, B, and C hereof.

THIS PERMIT SHALL EXPIRE AT MIDNIGHT, 12/31/99.

The authority granted by this permit is subject to the following further qualifications:

1. If there is a conflict between the application, its supporting documents and/or amendments and the terms and conditions of this permit, the terms and conditions shall apply.
2. Failure to comply with the terms, conditions, or effluent limitations of this permit is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
3. Complete application for renewal of this permit, or notification of intent to cease discharging by the expiration date, must be submitted to the Department at least 180 days prior to the above expiration date (unless permission has been granted by the Department for submission at a later date), using the appropriate NPDES permit application form.

In the event that a timely and complete application for renewal has been submitted and the Department is unable, through no fault of the permittee, to reissue the permit before the above expiration date, the terms and conditions of this permit, including submission of the Discharge Monitoring Reports, will be automatically continued and will remain fully effective and enforceable pending the grant or denial of the application for permit renewal.

4. This NPDES permit does not constitute authorization to construct or make modifications to wastewater treatment facilities necessary to meet the terms and conditions of this permit.

DATE PERMIT ISSUED _____

ISSUED BY DATE PERMIT AMENDMENT ISSUED 5-5-95

TITLE: Water Management Program Manager

DATE EFFECTIVE _____

I. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS FOR DISCHARGES LISTED BELOW:

<u>OUTFALLS</u>	<u>LATITUDE</u>	<u>LONGITUDE</u>	<u>WHICH RECEIVES WASTE FROM</u>	<u>DISCHARGES TO</u>
002	40°13'17"	75°35'15"	Area around STP and service roads	Possum Hollow Run
003 **	40°13'17"	75°35'14"	Chillers, floor drains, area around turbine units 1 and 2 and reactors 1 and 2	Possum Hollow Run
004	40°13'18"	75°35'07"	Fuel Storage Area	Possum Hollow Run
005 **	40°13'19"	75°35'05"	Turbine 2 area, circulation water pump structure and parking lots	Possum Hollow Run
012	40°13'15"	75°35'23"	Schuylkill River pump house, service roads	Possum Hollow Run
022	40°13'12"	75°35'16"	Area around STP and service roads	Possum Hollow Run
023 *	40°13'11"	75°35'17"	Cooling tower emergency overflow vent	Possum Hollow Run

- A. The permittee is authorized to discharge during the period from issuance through expiration.
- B. Based on production data and anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply:
1. This discharge shall consist solely of storm water runoff.
 2. There shall be no discharge of floating solids or visible foam in other than trace amounts.
 3. This discharge is subject to the terms and conditions of the General Permit for Discharges of Storm Water from Industrial Activities, PAG-3, as issued on November 7, 1992 which is attached and made part of this permit. Monitoring Requirements listed under Appendix J are applicable.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s). At any one Outfall of the above listed Outfalls.

- * In addition during discharge of cooling tower blowdown through Outfall 023 a grab sample must be collected at Outfall 023 and be analyzed for those pollutants listed on page 2 and 2a, using the sample frequency and type as indicated on the DMRs of such Outfall(s).
- ** During discharge of condenser waterbox wastewater through Outfall(s) 003 and/or 005 a grab sample must be collected at the corresponding initial monitoring point(s) 103 and/or 105 and be analyzed for those pollutants listed on page 2 and 2a with the exception of temperature using same procedure as for 023 above. Temperature shall be measured at Outfall(s) 003 and/or 005.

(RN)10

INSTRUCTIONS FOR UTILIZING
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT

The original DMR form(s) included with your permit are provided to serve as a master. Copies of this form must be used when reporting the results of the monitoring requirements in your permit. Do not write on or send the original master. If you receive computer generated preprinted DMR forms they should be used in place of the enclosed forms.

A "Monitor Only" or "Report" contained in a permit requirement block indicates that the parameter is monitored and the test result reported in the appropriate block. Any test methods specified in Part C of the permit must be used.

An "Average Weekly" value is defined as the highest weekly average value observed during the monthly monitoring period.

For parameters for which the effluent limit is lower than the Method Detection Limit (MDL) of the most sensitive existing EPA approved (40 CFR Part 136) test method or DER approved method, the parameters should be analyzed using the test method specified in Part C of the permit. The sample results must be specified on the DMR form as either the measured (quantified) value or as "less than" the detection limit used in the test (eg. < x.x). Results SHALL NOT be reported as "Not Detectable" or ND. For computing monthly averages, all "less than" sample results may be counted as zero values. All sample results used in computing monthly average values must be reported on the DMR form in the DMR comment section.

Loading or mass units shall be reported as the average of the calculated daily loadings during the monthly (or weekly) measurement period.

You should also note any other special instructions or definitions contained on the front and back of the DMR as well as page 3 and 4 of the permit.

Submit the completed forms to the State, EPA and County Health Department as required in the permit.

To Calculate Mass of Pollutants For a Sampling Event

Use the sampling event reported concentration and perform the appropriate calculation as follows:

$$\text{concentration } (\mu\text{g/l}) \times 0.00834 \times \text{flow (million gallons/day)} = \text{lb/day}$$

or

$$\text{concentration (mg/l)} \times 8.34 \times \text{flow (million gallons/day)} = \text{lb/day}$$

The value assigned to "flow (million gallons/day)" should be the 24-hour average flow for the outfall on the day the sample was taken. Where an outfall discharges for only part of a day (x hours), the daily mass value should be determined by using the x-hour average flow.

To Calculate an Arithmetic Average or Mean

Use the following equation:

$$\frac{X_1 + X_2 + X_3 + X_4 + \dots + X_n}{n}$$

where n = number of results

X = value of each analytical result

For example,

five samples were analyzed, their results were 75, 82, 90, 70, 88.

$$\frac{75 + 82 + 90 + 70 + 88}{5} = 80.4$$

To Calculate a Geometric Mean or Geometric Average (For Fecal Coliform Only)

Use the following equation:

$$\sqrt[n]{X_1 \times X_2 \times X_3 \times X_4 \times \dots \times X_n}$$

where n = number of analysis results

X = value of each analytical result

Note: If any value of X is zero, substitute a 1.0 for the calculation.

For example,

five samples were analyzed, their results were 75, 82, 90, 70, 88.

$$\sqrt[5]{75 \times 82 \times 90 \times 70 \times 88} = \sqrt[5]{3,293,325,000} = 80.1$$

To Calculate Average of Values Expressed as "Less than Numbers"

When averaging a series of values which are all expressed as "less than" values, add those numbers and divide by the number of values. Report it as "less than" that average number.

For example, the results are < 10, < 50 and < 25.

Calculate the average as $(10 + 50 + 25) \div 3 = < 28.3$.

When the series of values to be averaged is a mixture of real numbers and "less than" numbers, add all the numbers and divide by the number of values. The method of reporting the results will depend on the relative frequency of occurrences of "less than" numbers, and the relative difference in magnitude of the sample results. For example:

The average of < 10, < 25, 40

would be reported as < 25

The average of < 10, 40, 70

would be reported as 40

The average of < 10, < 10, 100

would be reported as 40

PERMITTEE NAME/ADDRESS (Include:

Facility Name/Location if different)

NAME PECO Energy Company

ADDRESS 2301 Market Street

Philadelphia, PA 19101

FACILITY Limerick Generating Station

LOCATION Limerick Township, Montgomery Co.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PA 0051926

Amendment No. 1

MP103

DISCHARGE NUMBER

This form must be used during discharge of cooling tower blowdown through 003.

* Sample during discharge to drain valves associated with Unit 1 pumps.

MONITORING PERIOD

FROM			TO		
YEAR	MO	DAY	YEAR	MO	DAY
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION				NO. EX (62-67)	FREQUENCY OF ANALYSIS (68-69)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
		MONTHLY	DAILY			MONTHLY	DAILY				
FLOW	SAMPLE MEASUREMENT			GPD							
	PERMIT REQUIREMENT	MONITOR/REPORT	MONITOR/REPORT						*	EST.	
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT				MONITOR/REPORT	MONITOR/REPORT	MG/L	*	GRAB		
TEMPERATURE at Outfall 003	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT					110	°F	*	I-S		
TOTAL RESIDUAL OXIDANTS	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT					0.2	MG/L	*	GRAB		
ZINC, TOTAL	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT					0.7	1.0	MG/L	*	GRAB	
COPPER, TOTAL **	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT					0.14	0.28	MG/L	*	GRAB	
PHOSPHORUS AS P	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT				MONITOR/REPORT	MONITOR/REPORT	MG/L	*	GRAB		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT, SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)				TELEPHONE		DATE				
TYPED OR PRINTED					SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

** These limits are effective October 1, 1995. Until such time monitor and report.

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)
NAME PECO Energy Company

ADDRESS 2301 Market Street
Philadelphia, PA 19101

FACILITY Limerick Generating Station
LOCATION Limerick Township, Montgomery County

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)
PA 0051926

Amendment No. 1

(17-19)
MP103

DISCHARGE NUMBER

Form Approved.

OMB No. 2040-0004

Approval expires 10-31-94

MONITORING PERIOD						
FROM			TO			
YEAR	MO	DAY	YEAR	MO	DAY	
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)	

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE MONTHLY	MAXIMUM DAILY			
HYDROTHOL 191	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT					0.07	0.14		1/MO	GRAB
BETZ-3625	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT					0.2	0.4		1/WK	GRAB
CLAMTROL CT-1	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT					0.2	0.4		1/WK	GRAB
pH	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT				INST. MIN 6.0		INST. MAX. 9.0	STD	1/WK	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE		DATE	
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER
TYPED OR PRINTED				YEAR	MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

This form must be used during discharge of cooling tower blowdown through 003.

* Sample during discharge at drain valves associated with Unit 1 pumps.

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)
NAME PECO Energy Company

ADDRESS 2301 Market Street
Philadelphia, PA 19101

FACILITY Limerick Generating Station
LOCATION Limerick Township, Montgomery Co.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

PA 0051926

MP105

Amendment No. 1

PERMIT NUMBER

DISCHARGE NUMBER

This form must be completed during discharge
of cooling tower blowdown through 005
* Sample during discharge through 005
valves associated with Unit-2 pumps.

MONITORING PERIOD

FROM YEAR MO DAY TO YEAR MO DAY
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only)			QUALITY OR CONCENTRATION (4 Card Only)				NO. EX (52-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE MONTHLY (32-33)	MAXIMUM DAILY (34-35)	UNITS (36-37)	MINIMUM (38-39)	AVERAGE MONTHLY (40-41)	MAXIMUM DAILY (42-43)	UNITS (44-45)			
FLOW	PERMIT REQUIREMENT	MONITOR/REPORT	MONITOR/REPORT	GPD						*	EST.
TOTAL SUSPENDED SOLIDS	PERMIT REQUIREMENT					MONITOR/REPORT	MONITOR/REPORT	MG/L		*	GRAB
TEMPERATURE at Outfall 005	PERMIT REQUIREMENT						110	°F		*	I-S
TOTAL RESIDUAL OXIDANTS	PERMIT REQUIREMENT						0.2	MG/L		*	GRAB
ZINC, TOTAL	PERMIT REQUIREMENT					0.7	1.0	MG/L		*	GRAB
COPPER, TOTAL **	PERMIT REQUIREMENT					0.14	0.28	MG/L		*	GRAB
PHOSPHORUS AS P	PERMIT REQUIREMENT					MONITOR/REPORT	MONITOR/REPORT	MG/L		*	GRAB
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)				TELEPHONE		DATE			
TYPED OR PRINTED						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

** These limits are effective October 1, 1995. Until such time monitor and report.

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME PECO Energy Company

ADDRESS 2301 Market Street

Philadelphia, PA 19101

FACILITY Limerick Generating Station

LOCATION Limerick Township, Montgomery County

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PA 0051926

Amendment No. 1

PERMIT NUMBER

MP105

DISCHARGE NUMBER

This form must be used during discharge of cooling tower blowdown through 005. * Sample during discharge at drain valves associated with Unit-2 pumps.

MONITORING PERIOD

FROM YEAR MO DAY TO YEAR MO DAY
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53) (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	OVERAGE MONTHLY	DAILY MAXIMUM	UNITS			
HYDROTHOL 191	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT					0.07	0.14	MG/L		1/MO	GRAB
BETZ-3625	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT					0.2	0.4	MG/L		1/WK	GRAB
CLAMTROL CT-1	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT					0.2	0.4	MG/L		1/WK	GRAB
PH	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT				INST. MIN 6.0		INST. MAX. 9.0	STD		1/WK	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

TYPED OR PRINTED

AREA CODE

NUMBER

YEAR

MO

DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

(RN)7