

CONTROL BLOCK:

						(1)
--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	Z	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	LICENSE NUMBER												25	LICENSE TYPE					30	57 CAT 58		

CON'T

0 1 7 8 REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 8 1 7 8 1 8 0 1 2 8 8 3 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During routine surveillance, it was discovered that suppression chamber water level

0 3 indicator, 2-CAC-LI-2601-3, was indicating a lower level than the other suppression

0 4 chamber water level indicator. On 8/20/81, the 2601-3 indicated a higher water

0 5 level than the other indicator and on 8/23/81, it again indicated a lower water

0 6 level than the other indicator. These events did not affect the health and safety

0 7 of the public.

Technical Specifications 3.3.5.3, 6.9.1.9b

SYSTEM CODE I E 11		CAUSE CODE B 12		CAUSE SUBCODE A 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE T 15		VALVE SUBCODE Z 16	
EVENT YEAR 8 1		SEQUENTIAL REPORT NO. 0 9 0		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NC 3			
ACTION TAKEN X 18		FUTURE ACTION C 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 22		ATTACHMENT SUBMITTED N 23	
NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER B 0 4 C 26							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Each event occurred due to changes in the trickle flow to the wet reference leg of

1 1 the indicator transmitter, 2-CAC-LT-2601, Model No. B015221, causing the transmitter

1 2 to be out of calibration. In each case, the trickle flow was properly established,

1 3 the transmitter was calibrated, and the indicator returned to service. Plant

1 4 modifications have been developed to eliminate future similar events.

FACILITY STATUS (28) F
 % POWER (29) 0 8
 OTHER STATUS (30) NA
 METHOD OF DISCOVERY (31) A
 DISCOVERY DESCRIPTION (32) Operator Surveillance
 ACTIVITY CONTENT
 RELEASED OF RELEASE (33) Z
 AMOUNT OF ACTIVITY (34) NA
 LOCATION OF RELEASE (35) NA
 PERSONNEL EXPOSURES
 NUMBER (36) 0 0 0
 TYPE (37) Z
 DESCRIPTION (38) NA
 PERSONNEL INJURIES
 NUMBER (39) 0 0 0
 DESCRIPTION (40) NA
 LOSS OF OR DAMAGE TO FACILITY
 TYPE (41) Z
 DESCRIPTION (42) NA
 PUBLICITY
 ISSUED (43) N
 DESCRIPTION (44) NA
 8302030510 830128
 PDR ADOCK 05000324
 S PDR
 NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: (919) 457-9521