



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 28, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303


Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Smoke Detection Zone 2-17
Alarmed and Would Not Reset
LER 82-185/03 L-0
AECM-83/66

On December 29, 1982, smoke detection Zone 2-17 alarmed and would not reset. A Limiting Condition for Operation was entered and a fire watch was established in accordance with Technical Specification 3.3.7.9. This event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 82-185/03 L-0.

Yours truly,


J. P. McGaughy, Jr.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302030562 830128
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY
1522