

Arizona Public Service Company

April 10, 1984  
ANPP-29269-BSK/TRB

U. S. Nuclear Regulatory Commission  
Region V  
Creskide Oaks Office Park  
1450 Maria Lane - Suite 210  
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director  
Division of Resident  
Reactor Projects and Engineering Programs

Subject: Interim Report - DER 84-12  
A 50.55(e) Potentially Reportable Deficiency Relating to Zone  
III Violations of RCP 1A and S/G #1  
File: 84-019-026; D.4.33.2


Reference: Telephone Conversation between P. Narbut and T. Bradish on  
March 14, 1984

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the  
referenced telephone conversation. At that time, it was estimated that a  
determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim  
Report is attached. It is now expected that this information will be  
finalized by June 1, 1984, at which time a complete report will be  
submitted.

Very truly yours,



E. E. Van Brunt, Jr.  
APS Vice President, Nuclear  
ANPP Project Director

EEVB/TRB:db

Attachment

cc: See Page Two

8404200306 840410  
PDR ADOCK 05000528  
S PDR

RECEIVED  
MAY 1 1984

10-27 11

Mr. T. W. Bishop  
ANPP- 29269  
Page Two

cc: Richard DeYoung, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

T. G. Woods, Jr.  
W. E. Ide  
D. B. Fasnacht  
A. C. Rogers  
B. S. Kaplan  
L. A. Souza  
J. Vorees  
J. R. Bynum  
P. P. Klute  
A. C. Gehr  
W. J. Stubblefield  
W. G. Bingham  
R. L. Patterson  
R. W. Welcher  
H. D. Foster  
D. R. Hawkinson  
L. E. Vorderbrueggen  
G. A. Fiorelli  
S. R. Frost  
J. Self  
D. Canady

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, GA 30339

INTERIM REPORT - DER 84-12  
POTENTIAL REPORTABLE DEFICIENCY  
ARIZONA PUBLIC SERVICE COMPANY (APS)  
FVNGS UNIT 1

I. Potential Problem

- A. The Zone III in RCP 1A, Unit 1 was violated when a barrier was removed inside the discharge line exposing the pump to grinding residue and lack of material accountability.
- B. The Zone III and cleanliness level in Steam Generator #1, Unit 1 was violated due to removal of the manway cover without zone coordination and control, allowing grinding residue to enter the Steam Generator.

II. Approach to and Status of Proposed Resolution

Bechtel Engineering is currently corresponding with C-E to determine reportability.

III. Projected Completion of Corrective Action and Submittal of the Final Report

Evaluation of this condition and submittal of the Final Report is Forecast to be completed by June 1, 1984.