

DUKE POWER COMPANY
P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

February 14, 1984

Mr. J. P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Subject: McGuire Nuclear Station, Unit 1
Docket No. 50.569
Snubber Functional Tests Sampling Plan (T.S.4.7.8e)

Dear Mr. O'Reilly:

Technical Specification Surveillance Requirement 4.7.8 states that each snubber required by T.S.3.7.8 shall be demonstrated operable by performance or an Augmented Inservice Inspection Program (as given in T.S.4.7.8a-i) and the requirements of Specification 4.0.5. Part of this Augmented Inspection Program (T.S.4.7.8e) is that during the first refueling shutdown and at least once per refueling thereafter, a representative sample of snubbers shall be tested using one of the three sample plans given. The sample plan is to be selected and the NRC notified prior to the test period.

McGuire Unit 1 first refueling shutdown is currently scheduled for February 25, 1984. Accordingly, this letter constitutes notification that Duke Power Company has selected sample plan No. 2 for the functional testing which is to be performed during the shutdown. This plan involves functionally testing a representative sample of the snubbers in accordance with T.S. Figure 4.7.1.

Very truly yours,

H.B. Tucker
Hal B. Tucker

PBN:glb

cc: Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
Attention: Ms. E. G. denham

Mr. W. T. Orders
Sr. Resident Inspector-NRC
McGuire Nuclear Station

8404200324 840412
PDR ADOCK 05000369
9 PDR