

February 18, 1983
SBN- 473
T.F. Q2.2.2

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Attention: Mr. Richard W. Starostecki, Director
Division of Resident and Project Inspection

References: (a) Construction Permit CPPR-135 and CPPR-136, Docket
Nos. 50-443 and 50-444
(b) PSNH Letter, dated June 17, 1982, "Potentially Reportable
10CFR50.55(e) Deficiency Interim Report on Electrical Cable
Tray Support Bolts," J. DeVincentis to Office of Inspection
and Enforcement (Region I)
(c) UE&C Letter, dated December 6, 1982, G. E. Sarston to
Director, Office of Inspection and Enforcement

Subject: Interim 10CFR50.55(e) Report; Electrical Cable Tray Support
Bolts

Dear Sir:

On Monday, July 27, 1981, we reported a potential 10CFR50.55(e) deficiency regarding an inconsistency in design information between test data, catalog data, and design allowables for Cable Tray Support Systems. Specifically, the Strut Support Systems used for certain bolted strut fittings, could be subjected to slippage at loads less than the published allowable loads.

In Reference (b) we provided an interim report on this item, and indicated that we would submit another report by February 10, 1983.

In Reference (c), UE&C provided the status and efforts taken to date to resolve this concern, and committed to completing an updated report by December 6, 1983.

The purpose of this letter is to inform you that we plan to submit a final report on this subject by January 31, 1984, following our review of the UE&C report.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

J. DeVincentis
J. DeVincentis
Project Manager

8302250033 830219
PDR ADOCK 05000443
S PDR

ALL/fsf

cc: Atomic Safety and Licensing Board Service List

IE27

ASLB SERVICE LIST

Philip Ahrens, Esquire
Assistant Attorney General
Department of the Attorney
General
Augusta, ME 04333

Representative Beverly Hollingworth
Coastal Chamber of Commerce
209 Winnacunnet Road
Hampton, NH 03842

William S. Jordan, III, Esquire
Harmon & Weiss
1725 I Street, N.W.
Suite 506
Washington, DC 20006

E. Tupper Kinder, Esquire
Assistant Attorney General
Office of the Attorney General
208 State House Annex
Concord, NH 03301

Robert A. Backus, Esquire
116 Lowell Street
P. O. Box 516
Manchester, NH 03105

Edward J. McDermott, Esquire
Sanders and McDermott
Professional Association
408 Lafayette Road
Hampton, NH 03842

Jo Ann Shotwell, Esquire
Assistant Attorney General
Environmental Protection Bureau
Department of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108