

Charles W. Jackson
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Ave.,
Buchanan, NY 10511
Telephone (514) 737-8116

Date: February 14, 1983

re: Indian Point Unit No. 2
Docket No. 50-247

Mr. Ronald C. Haynes, Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Haynes:

In accordance with the Technical Specifications of Facility Operating License No. DPR-26, the following confirms notification on February 13, 1983 to the Duty Officer at the NRC Operations Center, by Mr. Michael Mueller of Consolidated Edison of a Reportable Occurrence LER 83-003. This event is the type defined in Technical Specification, Section 6.9.1.7.1.i.

At 1:45 P.M. on February 13, 1983 a Notification of an Unusual Event (NUE) was declared when the Reactor Coolant System leakage from the packing on Valve 731 exceeded the Technical Specification limit of 10 gpm. The Reactor Coolant System was brought to hot shutdown and a cooldown and depressurization commenced. With the Reactor Coolant System at 450°F and 1000 psi a Reactor Coolant leakage safety analysis determined the leakage to be 6 gpm. At 3:28 P.M. the NUE was terminated.

Consolidated Edison believes that this report also satisfies the requirements of 10 CFR Part 21.

Very truly yours,

Michael Blatt
For

cc: Mr. William McDonald, Director (2 copies)
Office of Management Information and
Program Control
c/o Distribution Services Branch, DDC, ADM
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Thomas Foley, Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

8302250420 830214
PDR ADOCK 05000247
S PDR

IE-22