



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 22, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Halon Fire Control Panel
Q1H13P917 Trouble Alarm
Annunciated and Would not
Reset
LER 83-030/99 X-0
AECM-83/0102

On January 9, 1983, during cold shutdown, Halon Fire Control Panel Q1H13P917 trouble alarm annunciated with no fire or smoke present and would not reset. A Limiting Condition for Operation was entered and an hourly fire watch was established in accordance with Technical Specification 3.7.6.4. Attached LER 83-030/99 X-0 is submitted as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

J. P. McGaughy, Jr.
FOR J. P. McGaughy, Jr.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

TE 22