



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 22, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Diesel Generator 12 and
Division 2 ECCS Declared
Inoperable Due to Failure
to Meet Air Start Receiver
Minimum Pressure
Surveillance Requirement
LER 83-037/03 L-0
AECM-83/0103

On January 23, 1983, while in shutdown, one air start receiver for Diesel Generator 12 was found pressurized less than the minimum pressure required by Technical Specification 4.8.1.1.2.a.7. Diesel Generator 12 and Division 2 ECCS were declared inoperable. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-037/03 L-0.

Yours truly,

FOR J.P. McGaughy, JR.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302280230 830222
PDR ADQCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22